

Findings for walkthrough Murray Hill Middle School: November 12th, 2019 (WXMHMS201900024B)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMHMS2019001487	Tight seal on ceiling tiles		gym	custodial	Yes
FXMHMS2019001488	Uncomfortable temperature	HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again.	105	building	No
FXMHMS2019001489	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Microwave and refrigerator	120	administration	Yes
FXMHMS201900148A	General Cleanliness/Dust	Dust and spiderwebs in upper windowsills	120	custodial	Yes
FXMHMS201900148B	Excessive stuffed animals		216	administration	Yes
FXMHMS201900148C	Tight seal on ceiling tiles	Stained ceiling tile near light	107	custodial	Yes
FXMHMS201900148D	Chemicals are capped	Maintain 18 inches clearance from the ceiling	216_closet		No
FXMHMS201900148E	Plumbing fixture leaking/draining slowly	Middle faucet does not turn off all the way	Restroom	building	No
FXMHMS201900148F	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Microwave and electric equipment	Closet	administration	Yes
FXMHMS2019001490	Artificial plants/trees		203	administration	Yes
FXMHMS2019001491	Uncomfortable temperature	HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again.	205	building	No
FXMHMS2019001492	Miscellaneous finding	Blocking electrical panels	Electrical closet on second floor next Boys Room	administration	Yes
FXMHMS201900149C	Uncomfortable temperature	Window open & HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again.	215	building	No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMHMS201900149D	Uncomfortable temperature	HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again.	203	building	No