

# Findings for walkthrough Folly Quarter Middle School: November 26th, 2019 (WXFQMS2019000261)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXFQMS201900158A	General Cleanliness/Dust		Guidance office	custodial	Yes
FXFQMS201900158B	Tight seal on ceiling tiles		Guidance office	custodial	Yes
FXFQMS201900158D	General Cleanliness/Dust		Office 1	custodial	Yes
FXFQMS201900158F	Artificial plants/trees	Artificial plant- dust	Conference room	administration	Yes
FXFQMS2019001590	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dust on fin	Conference room	custodial	Yes
FXFQMS2019001593	Tight seal on ceiling tiles		Stairwell	custodial	Yes
FXFQMS2019001595	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dust on fin	Office 3	custodial	Yes
FXFQMS2019001596	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dust on fin-supply	Office 3	custodial	Yes
FXFQMS2019001598	General Cleanliness/Dust	Dust on top of lockers	1_hall	custodial	Yes
FXFQMS201900159A	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dust on supply fin	1_hall	administration	Yes
FXFQMS201900159C	Uncomfortable temperature	Over cool and staff mentions over heating, as well	1	building	No
FXFQMS201900159F	Tight seal on ceiling tiles	Water stained tile near window	2	custodial	Yes
FXFQMS20190015A4	Tight seal on ceiling tiles		Custodial closet 2	custodial	Yes
FXFQMS20190015A6	Tight seal on ceiling tiles	Fresh water stains on ceiling tile above map poster	science_1	custodial	Yes
FXFQMS20190015A7	Tight seal on ceiling tiles		Chem storage	custodial	Yes
FXFQMS20190015A9	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dust on supply vent	science_2_hall	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXFQMS20190015AA	General Cleanliness/Dust	Dust on top of lockers	science_2_hall	custodial	Yes
FXFQMS20190015AB	Tight seal on ceiling tiles		science_2	custodial	Yes
FXFQMS20190015AC	Tight seal on ceiling tiles		Restroom	custodial	Yes
FXFQMS20190015AD	Elevated moisture per moisture meter		science_3	building	No
FXFQMS20190015AE	Elevated moisture per moisture meter		science_3	building	No
FXFQMS20190015AF	Tight seal on ceiling tiles	Stained ceiling tile	science_3	custodial	Yes
FXFQMS20190015B0	General Cleanliness/Dust	Dusty on top of lockers	3_hall	custodial	Yes
FXFQMS20190015B1	Tight seal on ceiling tiles		science_3_office	custodial	Yes
FXFQMS20190015B2	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Wall unit has grime	Server room	custodial	Yes
FXFQMS20190015B3	Tight seal on ceiling tiles	Small stain outside of computer lab	Hall	custodial	Yes
FXFQMS20190015B4	General Cleanliness/Dust	Dusty shelving	Tech resource	custodial	Yes
FXFQMS20190015B5	Tight seal on ceiling tiles		Related services room	custodial	Yes
FXFQMS20190015B6	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Water cooler?	Media office	administration	Yes
FXFQMS20190015B8	Blocked temperature sensors	Water cooler in corner with thermostat nearby false heat	Media office	administration	Yes
FXFQMS20190015BA	Elevated moisture per moisture meter	Some evidence of reoccurring moisture on sink back splash	Related services	building	No
FXFQMS20190015BB	General Cleanliness/Dust	Dusty lockers	Hall	custodial	Yes
FXFQMS20190015BC	Tight seal on ceiling tiles		Health science	custodial	Yes
FXFQMS20190015BD	General Cleanliness/Dust	Shelving Dusty in areas	Media	custodial	Yes
FXFQMS20190015BE	Tight seal on ceiling tiles		Hall	custodial	Yes
FXFQMS20190015BF	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty supply	Parent Volunteer Room	custodial	Yes
FXFQMS20190015C0	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty supply	Health room	custodial	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXFQMS20190015C1	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Some dirty supply	Front office	custodial	Yes
FXFQMS20190015C2	General Cleanliness/Dust	Some Dusty tops of furniture	Front office	custodial	Yes
FXFQMS20190015C3	Tight seal on ceiling tiles		Hallway outside of FACS	custodial	Yes
FXFQMS20190015C4	Tight seal on ceiling tiles		Storage	custodial	Yes
FXFQMS20190015C5	Tight seal on ceiling tiles		Storage	custodial	Yes
FXFQMS20190015C6	Tight seal on ceiling tiles		cafeteria	custodial	Yes
FXFQMS20190015C7	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		cafeteria	custodial	Yes
FXFQMS20190015C8	Tight seal on ceiling tiles	Already marked	Tech Ed Lab Closet	custodial	Yes
FXFQMS20190015C9	Tight seal on ceiling tiles	Loose ceiling tiles	Cafeteria service	custodial	Yes
FXFQMS20190015CA	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Supply pantry	custodial	Yes
FXFQMS20190015CB	Plumbing fixture leaking/draining slowly	Water on floor and past signs of tile damage	Prep room	building	No
FXFQMS20190015CD	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Stage	custodial	Yes