

Findings for walkthrough River Hill High School: October 26th, 2018

(WXRHHS201800006D)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS2018000121	Visible mold on surfaces due to elevated relative humidity/dew point		Health Room	building	Yes