

Findings for walkthrough River Hill High School: October 26th, 2018 (WXRHHS201800006D)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|----------|----------------------|-------------|--------|
| FXRHHS2018000121 | Visible mold on surfaces due to elevated relative humidity/dew point | | Health Room building | | Yes |