

Findings for walkthrough Northfield Elementary School: September 24th, 2018

(WXXNES2018000074)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXNES201800012A	Relative humidity above 70%		Room 145	building	Yes