

Findings for walkthrough Harper’s Choice Middle School: December 19th, 2019

(WXHCMS2019000274)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXHCMS20190016DC	Tight seal on ceiling tiles		603	custodial	Yes
FXHCMS20190016DD	Tight seal on ceiling tiles	By Green Door, right of corner light	607	custodial	Yes
FXHCMS20190016DE	Tight seal on ceiling tiles	Left of room, 5 tiles over, 3 up.	504	custodial	Yes
FXHCMS20190016DF	Tight seal on ceiling tiles	6 from left, 3 up.	502	custodial	Yes
FXHCMS20190016E0	Miscellaneous finding	Compressor is freezing.	Portable 93	building	No
FXHCMS20190016E1	Holes/Penetrations in Wall	Damaged skirt - back left of portable.	Portable 91	building	No
FXHCMS20190016E2	Miscellaneous finding	Soap Dispenser.	Girls Bath by Terry's Office	custodial	Yes
FXHCMS20190016E3	Tight seal on ceiling tiles	Corner of room near vertical pipes.	202	custodial	Yes
FXHCMS20190016E4	Tight seal on ceiling tiles	Ceiling tile not sitting in grid properly.	C4	custodial	Yes
FXHCMS20190016E5	Miscellaneous finding	Minor Damage on Fiberglass pipe insulation.	FACS - Laundry Room	building	No
FXHCMS20190016E6	Chemicals are capped	Missing escutcheon plate	204	building	No
FXHCMS20190016E7	Tight seal on ceiling tiles		Boys Locker Room - Teacher/Coach Bathroom	custodial	Yes
FXHCMS20190016E8	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		Girls Locker Room	administration	Yes
FXHCMS20190016E9	Relative humidity above 70%		802	custodial	Yes
FXHCMS20190016EA	Miscellaneous finding	Missing Stat Cover	Portable 92	building	No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXHCMS20190016EB	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty Return Grille	Portable 92	custodial	Yes