

Findings for walkthrough Centennial High School: November 13th, 2018 (WXXCHS2018000080)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCHS201800015D	Electrical wiring exposed or disconnected wires	Needs cord cover	204	custodial	Yes
FXXCHS201800015E	Electrical wiring exposed or disconnected wires	Needs cord cover	104	custodial	Yes
FXXCHS201800015F	Electrical wiring exposed or disconnected wires	Needs cord cover	103	custodial	Yes
FXXCHS2018000160	Electrical wiring exposed or disconnected wires	Needs cord cover	302	custodial	Yes
FXXCHS2018000161	Electrical wiring exposed or disconnected wires	Needs cord cover	202	administration	Yes
FXXCHS2018000162	Electrical wiring exposed or disconnected wires	Needs cord cover	304	custodial	Yes
FXXCHS2018000163	Electrical wiring exposed or disconnected wires	Needs cord cover	Portable 3	custodial	Yes
FXXCHS2018000164	Electrical wiring exposed or disconnected wires	Needs cord cover	Portable 2	custodial	Yes
FXXCHS2018000165	Electrical wiring exposed or disconnected wires	Needs cord cover	907	custodial	Yes
FXXCHS2018000166	Tight seal on ceiling tiles	Stained tile	203	custodial	Yes
FXXCHS2018000167	Tight seal on ceiling tiles	Stained tile	202	custodial	Yes
FXXCHS2018000168	Tight seal on ceiling tiles	Stained tile	208	custodial	Yes
FXXCHS2018000169	Tight seal on ceiling tiles	Stained tile	209	custodial	Yes
FXXCHS201800016A	Tight seal on ceiling tiles	Stained tile	302	custodial	Yes
FXXCHS201800016B	Tight seal on ceiling tiles	Stained tile	Outside special services	custodial	Yes
FXXCHS201800016C	Excessive stuffed animals	Light covered with cloth	Portable 2	administration	Yes
FXXCHS201800016D	Tight seal on ceiling tiles	Wet tile	Health room closet	custodial	Yes
FXXCHS201800016E	Tight seal on ceiling tiles	Wet tile	English office	custodial	Yes
FXXCHS201800016F	Tight seal on ceiling tiles	Wet tile	Dell lab	custodial	Yes
FXXCHS2018000170	Tight seal on ceiling tiles	Wet tile	Dell lab	custodial	Yes
FXXCHS2018000171	Tight seal on ceiling tiles	Broken tile	604	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCHS2018000172	Tight seal on ceiling tiles	Wet tile	Media office	custodial	Yes
FXXCHS2018000173	Tight seal on ceiling tiles	Wet tile	Media center	custodial	Yes
FXXCHS2018000174	Tight seal on ceiling tiles	Wet tile	Science storage	custodial	Yes
FXXCHS2018000175	Tight seal on ceiling tiles	Broken tile	516	custodial	Yes
FXXCHS2018000176	Obstruction(s) to airflow	Air vent return broken louvers	604	building	Yes
FXXCHS2018000177	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Carpet stains and tears	Media center	building	Yes
FXXCHS2018000178	Obstruction(s) to airflow	Rusted air return vents	Math/Science hallway	building	Yes
FXXCHS2018000179	Electrical outlets not secured, cover missing, frayed wires on equipment	Loose light fixture	406	building	Yes
FXXCHS201800017A	Excessive stuffed animals	Flag on wall	402	administration	Yes
FXXCHS201800017B	Excessive stuffed animals	Flag on wall	401	administration	Yes
FXXCHS201800017C	Miscellaneous finding	Partition needs paint	404	building	Yes
FXXCHS201800017D	Miscellaneous finding	Window blacked out	905	administration	Yes
FXXCHS201800017E	Tight seal on ceiling tiles	Broken ceiling tile	916	custodial	Yes
FXXCHS201800017F	Tight seal on ceiling tiles	Wet ceiling tile	915	custodial	Yes
FXXCHS2018000180	Elevated moisture per moisture meter	stained carpet	915	environmental	Yes
FXXCHS2018000181	Elevated moisture per moisture meter	stained carpet	412	custodial	Yes
FXXCHS2018000182	Miscellaneous finding	Paint peeling on walls	410	building	Yes
FXXCHS2018000183	Elevated moisture per moisture meter	stains on tile floor	912	environmental	Yes
FXXCHS2018000184	Electrical cords unsecured, extend across walkways, cord protectors not installed	Need cord protector	409	custodial	Yes
FXXCHS2018000185	Plumbing fixture leaking/draining slowly	Possible leak	Kitchen dishwasher area	custodial	Yes
FXXCHS2018000186	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty return	Stage craft	building	Yes
FXXCHS2018000187	Miscellaneous finding	Paint flaking on ducts	Stage craft	building	Yes
FXXCHS2018000188	Elevated moisture per moisture meter	Water staining on pipe (minor - should be sealed)	Stage craft	environmental	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCHS2018000189	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty diffusers	Auditorium	administration	Yes
FXXCHS201800018A	Tight seal on ceiling tiles	Stained ceiling tiles	Outside auditorium (broadway)	custodial	Yes
FXXCHS201800018B	Tight seal on ceiling tiles	3 Stained ceiling tiles	Snack bar	custodial	Yes
FXXCHS201800018C	Tight seal on ceiling tiles	Loose ceiling tiles	Outside 802	custodial	Yes
FXXCHS201800018D	Tight seal on ceiling tiles	Loose ceiling tiles	802	custodial	Yes
FXXCHS201800018E	Tight seal on ceiling tiles	Loose ceiling tiles	Boys locker room	custodial	Yes
FXXCHS201800018F	Electrical outlets not secured, cover missing, frayed wires on equipment	Missing electrical plate	Boys locker room	building	Yes
FXXCHS2018000190	Tight seal on ceiling tiles	Ceiling tile with hole in it	Boys locker room	custodial	Yes
FXXCHS2018000191	Tight seal on ceiling tiles	Stained ceiling tile	Weight room	custodial	Yes
FXXCHS2018000192	Tight seal on ceiling tiles	Stained ceiling tile	Across from 904	custodial	Yes
FXXCHS2018000193	Electrical outlets not secured, cover missing, frayed wires on equipment	Missing electrical plate	Outside 904	building	Yes
FXXCHS2018000194	Tight seal on ceiling tiles	Stained ceiling tile	Outside 904	custodial	Yes
FXXCHS2018000195	Miscellaneous finding	Exit sign needs to be changed	Near boys locker room	building	Yes
FXXCHS2018000196	Tight seal on ceiling tiles	Stained ceiling tile	55	custodial	Yes
FXXCHS2018000197	Miscellaneous finding	Lamps	908	administration	Yes
FXXCHS2018000198	Tight seal on ceiling tiles	Stained ceiling tile	Foods closet	custodial	Yes