

Findings for walkthrough Centennial High School: November 13th, 2018

(WXXCHS2018000080)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|---|--------------------------|--------------------------|----------------|--------|
| FXXCHS201800015D | Electrical wiring exposed or disconnected wires | Needs cord cover | 204 | custodial | Yes |
| FXXCHS201800015E | Electrical wiring exposed or disconnected wires | Needs cord cover | 104 | custodial | Yes |
| FXXCHS201800015F | Electrical wiring exposed or disconnected wires | Needs cord cover | 103 | custodial | Yes |
| FXXCHS2018000160 | Electrical wiring exposed or disconnected wires | Needs cord cover | 302 | custodial | Yes |
| FXXCHS2018000161 | Electrical wiring exposed or disconnected wires | Needs cord cover | 202 | administration | Yes |
| FXXCHS2018000162 | Electrical wiring exposed or disconnected wires | Needs cord cover | 304 | custodial | Yes |
| FXXCHS2018000163 | Electrical wiring exposed or disconnected wires | Needs cord cover | Portable 3 | custodial | Yes |
| FXXCHS2018000164 | Electrical wiring exposed or disconnected wires | Needs cord cover | Portable 2 | custodial | Yes |
| FXXCHS2018000165 | Electrical wiring exposed or disconnected wires | Needs cord cover | 907 | custodial | Yes |
| FXXCHS2018000166 | Tight seal on ceiling tiles | Stained tile | 203 | custodial | Yes |
| FXXCHS2018000167 | Tight seal on ceiling tiles | Stained tile | 202 | custodial | Yes |
| FXXCHS2018000168 | Tight seal on ceiling tiles | Stained tile | 208 | custodial | Yes |
| FXXCHS2018000169 | Tight seal on ceiling tiles | Stained tile | 209 | custodial | Yes |
| FXXCHS201800016A | Tight seal on ceiling tiles | Stained tile | 302 | custodial | Yes |
| FXXCHS201800016B | Tight seal on ceiling tiles | Stained tile | Outside special services | custodial | Yes |
| FXXCHS201800016C | Excessive stuffed animals | Light covered with cloth | Portable 2 | administration | Yes |
| FXXCHS201800016D | Tight seal on ceiling tiles | Wet tile | Health room closet | custodial | Yes |
| FXXCHS201800016E | Tight seal on ceiling tiles | Wet tile | English office | custodial | Yes |
| FXXCHS201800016F | Tight seal on ceiling tiles | Wet tile | Dell lab | custodial | Yes |
| FXXCHS2018000170 | Tight seal on ceiling tiles | Wet tile | Dell lab | custodial | Yes |
| FXXCHS2018000171 | Tight seal on ceiling tiles | Broken tile | 604 | custodial | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|---|-------------------------|----------------|--------|
| FXXCHS2018000172 | Tight seal on ceiling tiles | Wet tile | Media office | custodial | Yes |
| FXXCHS2018000173 | Tight seal on ceiling tiles | Wet tile | Media center | custodial | Yes |
| FXXCHS2018000174 | Tight seal on ceiling tiles | Wet tile | Science storage | custodial | Yes |
| FXXCHS2018000175 | Tight seal on ceiling tiles | Broken tile | 516 | custodial | Yes |
| FXXCHS2018000176 | Obstruction(s) to airflow | Air vent return broken louvers | 604 | building | Yes |
| FXXCHS2018000177 | Floor coverings not level or secure (tile, carpets, wood board, etc.) | Carpet stains and tears | Media center | building | Yes |
| FXXCHS2018000178 | Obstruction(s) to airflow | Rusted air return vents | Math/Science hallway | building | Yes |
| FXXCHS2018000179 | Electrical outlets not secured, cover missing, frayed wires on equipment | Loose light fixture | 406 | building | Yes |
| FXXCHS201800017A | Excessive stuffed animals | Flag on wall | 402 | administration | Yes |
| FXXCHS201800017B | Excessive stuffed animals | Flag on wall | 401 | administration | Yes |
| FXXCHS201800017C | Miscellaneous finding | Partition needs paint | 404 | building | Yes |
| FXXCHS201800017D | Miscellaneous finding | Window blacked out | 905 | administration | Yes |
| FXXCHS201800017E | Tight seal on ceiling tiles | Broken ceiling tile | 916 | custodial | Yes |
| FXXCHS201800017F | Tight seal on ceiling tiles | Wet ceiling tile | 915 | custodial | Yes |
| FXXCHS2018000180 | Elevated moisture per moisture meter | stained carpet | 915 | environmental | Yes |
| FXXCHS2018000181 | Elevated moisture per moisture meter | stained carpet | 412 | custodial | Yes |
| FXXCHS2018000182 | Miscellaneous finding | Paint peeling on walls | 410 | building | Yes |
| FXXCHS2018000183 | Elevated moisture per moisture meter | stains on tile floor | 912 | environmental | Yes |
| FXXCHS2018000184 | Electrical cords unsecured, extend across walkways, cord protectors not installed | Need cord protector | 409 | custodial | Yes |
| FXXCHS2018000185 | Plumbing fixture leaking/draining slowly | Possible leak | Kitchen dishwasher area | custodial | Yes |
| FXXCHS2018000186 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Dirty return | Stage craft | building | Yes |
| FXXCHS2018000187 | Miscellaneous finding | Paint flaking on ducts | Stage craft | building | Yes |
| FXXCHS2018000188 | Elevated moisture per moisture meter | Water staining on pipe (minor - should be sealed) | Stage craft | environmental | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|-------------------------------|-------------------------------|----------------|--------|
| FXXCHS2018000189 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Dirty diffusers | Auditorium | administration | Yes |
| FXXCHS201800018A | Tight seal on ceiling tiles | Stained ceiling tiles | Outside auditorium (broadway) | custodial | Yes |
| FXXCHS201800018B | Tight seal on ceiling tiles | 3 Stained ceiling tiles | Snack bar | custodial | Yes |
| FXXCHS201800018C | Tight seal on ceiling tiles | Loose ceiling tiles | Outside 802 | custodial | Yes |
| FXXCHS201800018D | Tight seal on ceiling tiles | Loose ceiling tiles | 802 | custodial | Yes |
| FXXCHS201800018E | Tight seal on ceiling tiles | Loose ceiling tiles | Boys locker room | custodial | Yes |
| FXXCHS201800018F | Electrical outlets not secured, cover missing, frayed wires on equipment | Missing electrical plate | Boys locker room | building | Yes |
| FXXCHS2018000190 | Tight seal on ceiling tiles | Ceiling tile with hole in it | Boys locker room | custodial | Yes |
| FXXCHS2018000191 | Tight seal on ceiling tiles | Stained ceiling tile | Weight room | custodial | Yes |
| FXXCHS2018000192 | Tight seal on ceiling tiles | Stained ceiling tile | Across from 904 | custodial | Yes |
| FXXCHS2018000193 | Electrical outlets not secured, cover missing, frayed wires on equipment | Missing electrical plate | Outside 904 | building | Yes |
| FXXCHS2018000194 | Tight seal on ceiling tiles | Stained ceiling tile | Outside 904 | custodial | Yes |
| FXXCHS2018000195 | Miscellaneous finding | Exit sign needs to be changed | Near boys locker room | building | Yes |
| FXXCHS2018000196 | Tight seal on ceiling tiles | Stained ceiling tile | 55 | custodial | Yes |
| FXXCHS2018000197 | Miscellaneous finding | Lamps | 908 | administration | Yes |
| FXXCHS2018000198 | Tight seal on ceiling tiles | Stained ceiling tile | Foods closet | custodial | Yes |