

# Findings for walkthrough Centennial High School: January 24th, 2020 (WXXCHS20200002B4)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCHS2020001A59	Blocked temperature sensors	Vending machines and microwave near thermostats can cast off heat	Staff dining	administration	Yes
FXXCHS2020001A5A	Artificial plants/trees	Live plant in admin offices need drip pan	Front office suite	administration	Yes
FXXCHS2020001A5B	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Diffusers dirty	Music practice room at main door	custodial	Yes
FXXCHS2020001A5C	General Cleanliness/Dust		Student services hallway	custodial	Yes
FXXCHS2020001A5D	General Cleanliness/Dust	Dust on ledges	Student services hallway	custodial	Yes
FXXCHS2020001A5E	Blocked temperature sensors	Tv near thermostat	703	administration	Yes
FXXCHS2020001A5F	Tight seal on ceiling tiles		915	custodial	Yes
FXXCHS2020001A60	Tight seal on ceiling tiles	Stains near end of hall at stagecraft and exit doors near security camera and door to stage	701_hall	custodial	Yes
FXXCHS2020001A61	General Cleanliness/Dust		906	custodial	Yes
FXXCHS2020001A62	General Cleanliness/Dust		907	custodial	Yes
FXXCHS2020001A63	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Returns, exhaust, supply diffusers very dirty	Stagecraft	custodial	Yes
FXXCHS2020001A64	General Cleanliness/Dust		908	custodial	Yes
FXXCHS2020001A65	General Cleanliness/Dust		909	custodial	Yes
FXXCHS2020001A66	General Cleanliness/Dust		910	custodial	Yes
FXXCHS2020001A67	Miscellaneous finding	Remove clutter	Foods storage	administration	Yes
FXXCHS2020001A69	General Cleanliness/Dust		911	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCHS2020001A6A	Plumbing fixture leaking/draining slowly	Leaking sink	Foods pantry	building	No
FXXCHS2020001A6B	General Cleanliness/Dust		912	custodial	Yes
FXXCHS2020001A6D	General Cleanliness/Dust	Food containers need to be wiped down	Foods pantry	custodial	Yes
FXXCHS2020001A6E	General Cleanliness/Dust		913	custodial	Yes
FXXCHS2020001A6F	General Cleanliness/Dust		918	custodial	Yes
FXXCHS2020001A70	General Cleanliness/Dust		Storage closet	custodial	Yes
FXXCHS2020001A71	General Cleanliness/Dust		Storage closet	custodial	Yes
FXXCHS2020001A72	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Return vent louvers are missing	604	administration	Yes
FXXCHS2020001A73	General Cleanliness/Dust		Storage closet	custodial	Yes
FXXCHS2020001A74	Miscellaneous finding	Floor drain needs to be flushed	604	custodial	Yes
FXXCHS2020001A75	Tight seal on ceiling tiles	Stained and missing tiles in loft	Drill team guard storage	custodial	Yes
FXXCHS2020001A77	General Cleanliness/Dust	Need to remove clutter	Sendin office	administration	Yes
FXXCHS2020001A78	General Cleanliness/Dust		Storage closet	custodial	Yes
FXXCHS2020001A79	Tight seal on ceiling tiles	Water stain in very narrow portion corner of the area	Concession stand	custodial	Yes
FXXCHS2020001A7A	General Cleanliness/Dust		914	custodial	Yes
FXXCHS2020001A7B	Elevated moisture per moisture meter	Left end of stage high up pipe insulation to mechanical room heavily water stained	Stage	environmental	Yes
FXXCHS2020001A7C	Tight seal on ceiling tiles	Water stains near track lighting	803	custodial	Yes
FXXCHS2020001A7D	Miscellaneous finding	Corrosion on stall fixtures	Boys bathroom tech hall		No
FXXCHS2020001A7E	Elevated moisture per moisture meter	Exterior end wall above metal shelving cmu has black staining possible mold. Looks like material was stored against wall and may have left staining. The metal roof deck above has signs of water damage. Clean wall and assess water entry. Correct and refinish wall	Storage room near boiler room	building	No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCHS2020001A7F	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Carpet stained in multiple places	Media center	custodial	Yes
FXXCHS2020001A80	Tight seal on ceiling tiles		307	custodial	Yes
FXXCHS2020001A81	General Cleanliness/Dust	Floor needs to scrubbed	Dark room	custodial	Yes
FXXCHS2020001A82	Tight seal on ceiling tiles	Water stain and missing in entry hall within boiler room	Boiler room	custodial	Yes
FXXCHS2020001A83	General Cleanliness/Dust		Trainers office	custodial	Yes
FXXCHS2020001A84	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Carpet stained	104	custodial	Yes
FXXCHS2020001A85	Artificial plants/trees	Drip pan for plant	103		No
FXXCHS2020001A86	Tight seal on ceiling tiles	Metal roof deck along back exterior wall. Sections along perimeter edge has staining.	Auxiliary gym	custodial	Yes
FXXCHS2020001A87	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Carpet stains	202	custodial	Yes
FXXCHS2020001A88	Tight seal on ceiling tiles	Stained tiles	201	custodial	Yes
FXXCHS2020001A8A	Tight seal on ceiling tiles	Stain around drier vent pipe	Girls locker room ice machine laundry room	custodial	Yes
FXXCHS2020001A8B	Exterior doors not fully sealed (daylight)		903_hall	building	Yes
FXXCHS2020001A8C	Exterior doors not fully sealed (daylight)		912_hall	building	Yes
FXXCHS2020001A8E	Exterior doors not fully sealed (daylight)		408_hall	building	Yes
FXXCHS2020001A8F	Tight seal on ceiling tiles	Some type of staining around a sensor	Team room across from laundry room	custodial	Yes
FXXCHS2020001A91	Exterior doors not fully sealed (daylight)		900 Hall	building	Yes
FXXCHS2020001A96	Exterior doors not fully sealed (daylight)		506_hall	building	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXXCHS2020001A98	Tight seal on ceiling tiles	Painted tiles	409	custodial	Yes