

Findings for walkthrough Lisbon Elementary School: October 19th, 2018

(WXXLES2018000081)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXLES2018000199	Relative humidity above 70%		Room 115	building	Yes