

# Findings for walkthrough Cradlerock Elementary School: January 31st, 2020 (WXCRES20200002C2)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXCRES2020001B66	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		212	custodial	Yes
FXCRES2020001B67	Tight seal on ceiling tiles	Closet by vet 2 tiles	205	custodial	Yes
FXCRES2020001B69	Tight seal on ceiling tiles	Multiple tiles	Motor room	custodial	Yes
FXCRES2020001B6B	Artificial plants/trees	Fake plant	194	administration	Yes
FXCRES2020001B6D	Tight seal on ceiling tiles	2	Outside 184	custodial	Yes
FXCRES2020001B6F	Tight seal on ceiling tiles		045	custodial	Yes
FXCRES2020001B70	Tight seal on ceiling tiles	Tile above yellow cabinet... Check light as well... A little discolored	184	custodial	Yes
FXCRES2020001B72	Tight seal on ceiling tiles		050	custodial	Yes
FXCRES2020001B73	Tight seal on ceiling tiles		048	custodial	Yes
FXCRES2020001B74	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Floors around toilet	183	building	No
FXCRES2020001B75	Artificial plants/trees	Plant on cabinet	182	administration	Yes
FXCRES2020001B76	Chemicals are capped	Items hanging from ceiling and doorway blocked with clutter (emergency exit), spoke to teacher.	Portable	administration	Yes
FXCRES2020001B78	Tight seal on ceiling tiles		156	custodial	Yes
FXCRES2020001B79	Tight seal on ceiling tiles		Hallway	custodial	Yes
FXCRES2020001B7A	Tight seal on ceiling tiles		151	custodial	Yes
FXCRES2020001B7B	Tight seal on ceiling tiles		011	custodial	Yes
FXCRES2020001B7C	Tight seal on ceiling tiles		149	custodial	Yes
FXCRES2020001B7D	Tight seal on ceiling tiles		AP Office	custodial	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXCRES2020001B80	Tight seal on ceiling tiles		156	custodial	Yes
FXCRES2020001B81	Tight seal on ceiling tiles		22	custodial	Yes
FXCRES2020001B82	Tight seal on ceiling tiles		006	custodial	Yes
FXCRES2020001B83	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Lamp	016	administration	Yes
FXCRES2020001B84	Miscellaneous finding	Peeling paint	006	building	No
FXCRES2020001B85	Tight seal on ceiling tiles		Front hallway	custodial	Yes
FXCRES2020001B89	Artificial plants/trees		033	administration	Yes
FXCRES2020001B8A	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Tiles by water fountain	Gym hall	building	No
FXCRES2020001B8C	Tight seal on ceiling tiles	Tile askew in foyer	057	custodial	Yes
FXCRES2020001B8E	Holes/Penetrations in Wall	Crack in corner of wall in closet with blue steel shelving	Equipment closets	building	No
FXCRES2020001B90	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty ceiling vent	PE offices	custodial	Yes
FXCRES2020001B92	Tight seal on ceiling tiles		PE offices	custodial	Yes