

Findings for walkthrough Longfellow Elementary School: February 11th, 2020

(WXLOES20200002CD)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXLOES2020001C13	Chemicals are capped	Housekeeping in storage 125, maintain a 3 foot walkway.	125	administration	Yes
FXLOES2020001C15	Tight seal on ceiling tiles	Stage ramp	120h	custodial	Yes
FXLOES2020001C17	Excessive stuffed animals	Numerous fabric materials. A plan is to be in place for regular cleaning.	116	administration	Yes
FXLOES2020001C19	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Lamps	129	administration	Yes
FXLOES2020001C1B	Miscellaneous finding	Paint peeling from access panel in ceiling	Girls Bath across from admin		No
FXLOES2020001C1D	Tight seal on ceiling tiles		Gym Storage	custodial	Yes
FXLOES2020001C1E	Electrical cords unsecured, extend across walkways, cord protectors not installed	Vacuum missing ground prong on electrical cord	Electrical 143	building	No
FXLOES2020001C20	Chemicals are capped		north_west_entrance_hall	administration	Yes
FXLOES2020001C21	Tight seal on ceiling tiles		210	custodial	Yes
FXLOES2020001C22	Excessive stuffed animals		210	administration	Yes
FXLOES2020001C23	Chemicals are capped	Improve housekeeping in vestibule as it is an emergency exit.	Vestibule Near 207	administration	Yes
FXLOES2020001C24	Chemicals are capped	Maintain 18" of clearance around sprinkler head.	205	administration	Yes