

Findings for walkthrough Longfellow Elementary School: February 11th, 2020 (WXLOES2020002CD)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|---|---|------------------------------|----------------|--------|
| FXLOES2020001C13 | Chemicals are capped | Housekeeping in storage 125, maintain a 3 foot walkway. | 125 | administration | Yes |
| FXLOES2020001C15 | Tight seal on ceiling tiles | Stage ramp | 120h | custodial | Yes |
| FXLOES2020001C17 | Excessive stuffed animals | Numerous fabric materials. A plan is to be in place for regular cleaning. | 116 | administration | Yes |
| FXLOES2020001C19 | Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA) | Lamps | 129 | administration | Yes |
| FXLOES2020001C1B | Miscellaneous finding | Paint peeling from access panel in ceiling | Girls Bath across from admin | | No |
| FXLOES2020001C1D | Tight seal on ceiling tiles | | Gym Storage | custodial | Yes |
| FXLOES2020001C1E | Electrical cords unsecured, extend across walkways, cord protectors not installed | Vacuum missing ground prong on electrical cord | Electrical 143 | building | No |
| FXLOES2020001C20 | Chemicals are capped | | north_west_entrance_hall | administration | Yes |
| FXLOES2020001C21 | Tight seal on ceiling tiles | | 210 | custodial | Yes |
| FXLOES2020001C22 | Excessive stuffed animals | | 210 | administration | Yes |
| FXLOES2020001C23 | Chemicals are capped | Improve housekeeping in vestibule as it is an emergency exit. | Vestibule Near 207 | administration | Yes |
| FXLOES2020001C24 | Chemicals are capped | Maintain 18" of clearance around sprinkler head. | 205 | administration | Yes |