

# Findings for walkthrough Long Reach High School: November 16th, 2018 (WXRHS201800008A)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXLRHS20180001C0	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Toaster oven	b103-2	administration	Yes
FXLRHS20180001C3	Chemicals are capped	Closet may need to be organized - possible egress issue if there is an emergency	Tech Ed storage	administration	Yes
FXLRHS20180001C5	Electrical cords unsecured, extend across walkways, cord protectors not installed		328	custodial	Yes
FXLRHS20180001C6	Electrical cords unsecured, extend across walkways, cord protectors not installed		326	custodial	Yes
FXLRHS20180001C7	Odors		324	environmental	Yes
FXLRHS20180001C8	Artificial plants/trees		322	administration	Yes
FXLRHS20180001C9	Excessive stuffed animals		322	administration	Yes
FXLRHS20180001CA	Excessive stuffed animals		320 Admin Office	administration	Yes
FXLRHS20180001CB	Artificial plants/trees		320 Admin Office	administration	Yes
FXLRHS20180001CC	Tight seal on ceiling tiles		b128	custodial	Yes
FXLRHS20180001CD	Visible mold (leak)	Possible in the corner	Stair well	environmental	Yes
FXLRHS20180001CE	Uncomfortable temperature		gym	building	No
FXLRHS20180001D0	Tight seal on ceiling tiles		a123	custodial	Yes
FXLRHS20180001D1	Tight seal on ceiling tiles		a123	custodial	Yes
FXLRHS20180001D2	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		b107a	administration	Yes
FXLRHS20180001D3	Electrical cords unsecured, extend across walkways, cord protectors not installed		318	custodial	Yes
FXLRHS20180001D4	Miscellaneous finding	Pipe covers missing	Girls bathroom	building	No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXLRHS20180001D6	Tight seal on ceiling tiles		b122	custodial	Yes
FXLRHS20180001D7	Tight seal on ceiling tiles		314_hall	custodial	Yes
FXLRHS20180001D8	Tight seal on ceiling tiles		auditorium_entrance_hall	custodial	Yes
FXLRHS20180001D9	Tight seal on ceiling tiles		b123	custodial	Yes
FXLRHS20180001DA	Artificial plants/trees		316	administration	Yes
FXLRHS20180001DB	Relative humidity above 70%		312	environmental	Yes
FXLRHS20180001DC	Tight seal on ceiling tiles		311	custodial	Yes
FXLRHS20180001DD	Tight seal on ceiling tiles		auditorium_side_hall	custodial	Yes
FXLRHS20180001DE	Electrical outlets not secured, cover missing, frayed wires on equipment		307	building	Yes
FXLRHS20180001DF	Tight seal on ceiling tiles		3rd floor C stairwell	custodial	Yes
FXLRHS20180001E0	Electrical cords unsecured, extend across walkways, cord protectors not installed		306	custodial	Yes
FXLRHS20180001E1	Artificial plants/trees		306	administration	Yes
FXLRHS20180001E2	Odors	Nail polish spill smell	306	environmental	Yes
FXLRHS20180001E4	Miscellaneous finding	Taxidermy hanging above door	306	administration	Yes
FXLRHS20180001E6	Tight seal on ceiling tiles		304	custodial	Yes
FXLRHS20180001E7	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		304	administration	Yes
FXLRHS20180001E8	Miscellaneous finding	Missing camera cover on ceiling	302_hall	building	No
FXLRHS20180001E9	Electrical cords unsecured, extend across walkways, cord protectors not installed		302	custodial	Yes
FXLRHS20180001EA	Tight seal on ceiling tiles	3 tiles are stained in the class. 2 missing at exit door. Wet tile at back door. Large trash bin blocking exit to catch water?	356	custodial	Yes
FXLRHS20180001EB	Tight seal on ceiling tiles	Two ceiling tiles	250	custodial	Yes
FXLRHS20180001EE	Miscellaneous finding	Missing covers on ceiling cameras and sprinkler heads dirty on side closest to library	Hallway	building	No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXLRHS20180001F0	Tight seal on ceiling tiles		354	custodial	Yes
FXLRHS20180001F1	Electrical cords unsecured, extend across walkways, cord protectors not installed		354	custodial	Yes
FXLRHS20180001F2	Electrical cords unsecured, extend across walkways, cord protectors not installed		348	custodial	Yes
FXLRHS20180001F3	Odors	Staff report carpet smells	348	environmental	Yes
FXLRHS20180001F5	Tight seal on ceiling tiles	Water stain near tv and in front of screen	350	custodial	Yes
FXLRHS20180001F6	Tight seal on ceiling tiles		353 Prep Room	custodial	Yes
FXLRHS20180001F8	Electrical cords unsecured, extend across walkways, cord protectors not installed		352	custodial	Yes
FXLRHS20180001F9	Electrical outlets not secured, cover missing, frayed wires on equipment	No emergency electrical shut-off, science room	356	building	Yes
FXLRHS20180001FA	Miscellaneous finding	No drain for eye wash and shower. Consider putting pig skins in room to absorb water if needed	352	building	No
FXLRHS20180001FE	Miscellaneous finding	No water pipe covers under sinks	Girl bathroom	building	No
FXLRHS2018000200	Tight seal on ceiling tiles		348	custodial	Yes
FXLRHS2018000201	Electrical cords unsecured, extend across walkways, cord protectors not installed		344	custodial	Yes
FXLRHS2018000202	Tight seal on ceiling tiles		343	custodial	Yes
FXLRHS2018000203	Electrical cords unsecured, extend across walkways, cord protectors not installed	Cords are tangled and overlapping power strip	343	custodial	Yes
FXLRHS2018000205	Tight seal on ceiling tiles	Water stain	340	custodial	Yes
FXLRHS2018000207	Miscellaneous finding	Tile and cardboard near warm electrical equipment.	339 electrical closet	custodial	Yes
FXLRHS2018000208	Miscellaneous finding	Damaged counter top edge	340	building	No
FXLRHS201800020B	Miscellaneous finding	Clearance issue n storage shelves, too close to ceiling	337	administration	Yes
FXLRHS201800020D	Relative humidity above 70%	Evidence of water damage on the window sill	334	environmental	Yes
FXLRHS201800020F	Excessive stuffed animals		334	administration	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXLRHS2018000210	Electrical cords unsecured, extend across walkways, cord protectors not installed		332	custodial	Yes
FXLRHS2018000211	Odors	When HVAC runs, musty smell	335	environmental	Yes
FXLRHS2018000213	Signs of insects or evidence of pest		335	building	Yes