

# Findings for walkthrough Worthington Elementary School: March 6th, 2020 (WXWOES20200002F5)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWOES2020001D72	General Cleanliness/Dust	Dust in storage closet	190	custodial	Yes
FXWOES2020001D73	Tight seal on ceiling tiles		120	custodial	Yes
FXWOES2020001D74	Artificial plants/trees	Artificial plants	195	administration	Yes
FXWOES2020001D75	Excessive stuffed animals	Stuffed animals	195	administration	Yes
FXWOES2020001D76	Excessive stuffed animals	Stuffed animals	196	administration	Yes
FXWOES2020001D7D	Miscellaneous finding	Light out	Room 108	administration	Yes
FXWOES2020001D8F	Miscellaneous finding	Maintain 18 inches clearance from the ceiling.	Storage 108 A	administration	Yes
FXWOES2020001DA0	Excessive stuffed animals		Room 112	administration	Yes
FXWOES2020001DA2	Miscellaneous finding	Maintain 18 inches clearance from the ceiling	Room 113	administration	Yes
FXWOES2020001DA3	General Cleanliness/Dust		Room 156	administration	Yes
FXWOES2020001DA8	Miscellaneous finding	Maintain 18 inches clearance from the ceiling	Room 164	administration	Yes
FXWOES2020001DAC	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Coffee maker	Room 167	administration	Yes
FXWOES2020001DAF	General Cleanliness/Dust	Objects blocking back exit door. Furniture not HCPSS provided	Room 177	administration	Yes
FXWOES2020001DB3	Artificial plants/trees		Room 102, 103 & 181	administration	Yes
FXWOES2020001DB6	Tight seal on ceiling tiles	on speaker system	Hallway by room 167	administration	Yes
FXWOES2020001DD7	Artificial plants/trees		Room 134	administration	Yes