

Findings for walkthrough Bollman Bridge Elementary School: August 15th, 2018 (WXBBES2018000090)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXBBES2018000214	Visible mold on surfaces due to elevated relative humidity/dew point		Gym Office	custodial	Yes