

Findings for walkthrough Fulton Elementary School: June 19th, 2020 (WXXFES2020000312)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXFES2020001ECF	Tight seal on ceiling tiles		Portable	building	Yes
FXXFES2020001ED0	Blocked temperature sensors		Portable	building	Yes
FXXFES2020001ED1	Elevated moisture per moisture meter		Portable	building	Yes