

Findings for walkthrough Fulton Elementary School: June 19th, 2020

(WXXFES2020000312)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--------------------------------------|----------|----------|-------------|--------|
| FXXFES2020001ECF | Tight seal on ceiling tiles | | Portable | building | Yes |
| FXXFES2020001ED0 | Blocked temperature sensors | | Portable | building | Yes |
| FXXFES2020001ED1 | Elevated moisture per moisture meter | | Portable | building | Yes |