

# Findings for walkthrough Veterans Elementary School: September 8th, 2020 (WXXVES202000031B)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXVES2020001ED8	Visible mold on surfaces due to elevated relative humidity/dew point		Portable 114	building	Yes
FXXVES2020001ED9	Visible mold on surfaces due to elevated relative humidity/dew point		Portable 114	administration	Yes