

Findings for walkthrough Centennial Lane Elementary School: November 20th, 2018 (WXCLES2018000096)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXCLES201800021F	Visible mold on surfaces due to elevated relative humidity/dew point		Activity Room Closet (room 219)	administration	Yes