

Findings for walkthrough Veterans Elementary School: September 10th, 2020

(WXXVES202000031F)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXVES2020001EDE	Visible mold on surfaces due to elevated relative humidity/dew point		Portable 114	building	Yes