

# Findings for walkthrough Centennial Lane Elementary School: October 28th, 2018

## (WXCLES2018000097)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXCLES2018000220	Visible mold on surfaces due to elevated relative humidity/dew point		Activity Room Closet (room 219)	custodial	Yes