

# Findings for walkthrough Running Brook Elementary School: August 24th, 2018

## (WXRBE20180000A1)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRBES201800022A	Visible mold on surfaces due to elevated relative humidity/dew point		Gymnasium Office	building	Yes