

# Findings for walkthrough Lake Elkhorn Middle School: January 19th, 2021

## (WXLEMS2021000345)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXLEMS2021001F03	Visible mold on surfaces due to elevated relative humidity/dew point		various classrooms throughout the building	environmental	Yes
FXLEMS2021001F06	Elevated moisture per moisture meter		various classrooms throughout the building	building	Yes