

# Findings for walkthrough Lake Elkhorn Middle School: January 19th, 2021 (WXLEMS2021000345)

| Tracking Number  | Finding Type   | Comments | Location                                   | Assigned To   | Closed |
|------------------|--|----------|--|---------------|--------|
| FXLEMS2021001F03 | Visible mold on surfaces due to elevated relative humidity/dew point |          | various classrooms throughout the building | environmental | Yes    |
| FXLEMS2021001F06 | Elevated moisture per moisture meter                                 |          | various classrooms throughout the building | building      | Yes    |