

# Findings for walkthrough Thomas Viaduct Middle School: November 27th, 2018

## (WXTVMS20180000A7)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTVMS201800023F	Tight seal on ceiling tiles		207	custodial	Yes
FXTVMS2018000240	Miscellaneous finding	Light fixture panel bowed	Staff restroom near admin	building	Yes
FXTVMS2018000242	Miscellaneous finding	2 cracks in ceiling & one light out	a51	building	Yes
FXTVMS2018000243	Miscellaneous finding	2 light fixtures with stains	a40	custodial	Yes
FXTVMS2018000245	Tight seal on ceiling tiles	Ceiling cracked around vent in handicap stall	214	building	Yes
FXTVMS2018000246	Elevated moisture per moisture meter	Under middle sink	a52	environmental	Yes
FXTVMS2018000247	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Damaged vent	a52	custodial	Yes
FXTVMS2018000248	Tight seal on ceiling tiles		242 stairwell	custodial	Yes
FXTVMS2018000249	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Possible dust and debris on return at front of class.	b03	custodial	Yes
FXTVMS201800024B	Visible mold (leak)	Floor sink - around edges Smells musty	a53	environmental	Yes
FXTVMS201800024C	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Back vent stained	a53	custodial	Yes
FXTVMS201800024E	Windows/Doors open	Missing caulk on window by exterior door	b36	building	Yes
FXTVMS2018000250	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty return difficult to access due to storage	B24 cafeteria storage	custodial	Yes
FXTVMS2018000252	General Cleanliness/Dust	Dirty under sink & soap - on the tile edge	a64	custodial	Yes
FXTVMS2018000253	General Cleanliness/Dust	Dirty under sink & soap on tile edge	a65	custodial	Yes
FXTVMS2018000254	Tight seal on ceiling tiles	Hole I. Ceiling above shower	Girls Locker Room	building	Yes