

# Findings for walkthrough Applications and Research Laboratory: July 20th, 2021

## (WXXARL2021000361)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXARL2021001F21	Visible mold (leak)		Hospitality Suite Bathroom	environmental	Yes
FXXARL2021001F22	Elevated moisture per moisture meter		Hospitality Suite Bathroom	building	Yes