## Findings for walkthrough Mount Hebron High School: August 17th, 2021 (WXMHHS2021000374)

<b>Tracking Number</b>	Finding Type	Comments	Location	Assigned To	Closed
FXMHHS2021001F36	Visible mold on surfaces due to elevated relative humidity/dew point	Portables building.	27, 61, 145 and other suspect areas within the main	building	Yes