

# Findings for walkthrough Mount Hebron High School: August 17th, 2021

## (WXMHHS2021000374)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMHHS2021001F36	Visible mold on surfaces due to elevated relative humidity/dew point		Portables 27, 61, 145 and other suspect areas within the main building.	building	Yes