

Findings for walkthrough Atholton Elementary School: August 20th, 2021 (WXXAES2021000376)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|----------|----------|---------------|--------|
| FXXAES2021001F38 | Visible mold on surfaces due to elevated relative humidity/dew point | | Room 106 | environmental | Yes |