

# Findings for walkthrough Wilde Lake High School: November 28th, 2018 (WXWLHS20180000AC)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLHS2018000256	Tight seal on ceiling tiles		214	custodial	Yes
FXWLHS2018000257	Miscellaneous finding	Heavy dust on sprinkler	218		No
FXWLHS2018000258	Miscellaneous finding	Heavy dust on ceiling grids	218		No
FXWLHS201800025B	Tight seal on ceiling tiles		212	custodial	Yes
FXWLHS201800025C	Miscellaneous finding	Loose supply diffuser	327		No
FXWLHS201800025E	General Cleanliness/Dust		209	custodial	Yes
FXWLHS201800025F	Tight seal on ceiling tiles		Outside of 319	custodial	Yes
FXWLHS2018000260	Tight seal on ceiling tiles		226	custodial	Yes
FXWLHS2018000261	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	High dusting	Media	administration	Yes
FXWLHS2018000262	General Cleanliness/Dust		217	custodial	Yes
FXWLHS2018000264	Miscellaneous finding	Need surge protectors	226		No
FXWLHS2018000265	General Cleanliness/Dust		211	custodial	Yes
FXWLHS2018000267	Tight seal on ceiling tiles		Principal office	custodial	Yes
FXWLHS2018000268	Tight seal on ceiling tiles		Principal office	custodial	Yes
FXWLHS2018000269	Miscellaneous finding	Need surge protectors	230		No
FXWLHS201800026B	Tight seal on ceiling tiles		Kirchners office	custodial	Yes
FXWLHS201800026C	Tight seal on ceiling tiles		223	custodial	Yes
FXWLHS201800026D	General Cleanliness/Dust		223	custodial	Yes
FXWLHS201800026E	Miscellaneous finding	Need surge protector. Coffee maker	236		No
FXWLHS2018000270	Tight seal on ceiling tiles		236	custodial	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXWLHS2018000271	Tight seal on ceiling tiles		238	custodial	Yes
FXWLHS2018000272	Floor coverings not level or secure (tile, carpets, wood board, etc.)		cafeteria	building	No
FXWLHS2018000273	Electrical outlets not secured, cover missing, frayed wires on equipment		cafeteria	building	No
FXWLHS2018000274	Electrical outlets not secured, cover missing, frayed wires on equipment		cafeteria	building	No
FXWLHS2018000275	Tight seal on ceiling tiles		231	custodial	Yes
FXWLHS2018000276	Tight seal on ceiling tiles		Cafeteria manager	custodial	Yes
FXWLHS2018000279	Tight seal on ceiling tiles		Cafeteria manager	custodial	Yes
FXWLHS201800027A	Electrical cords unsecured, extend across walkways, cord protectors not installed		Cafeteria manager	administration	Yes
FXWLHS201800027B	Tight seal on ceiling tiles		Pantry	custodial	Yes
FXWLHS201800027C	General Cleanliness/Dust		Upstairs balcony	custodial	Yes
FXWLHS201800027D	Floor coverings not level or secure (tile, carpets, wood board, etc.)		Staff locker room	building	No
FXWLHS201800027E	Tight seal on ceiling tiles		123	custodial	Yes
FXWLHS201800027F	Exterior doors not fully sealed (daylight)		Kitchen	building	No
FXWLHS2018000280	General Cleanliness/Dust		Hallway	custodial	Yes
FXWLHS2018000281	General Cleanliness/Dust		Overhang JRT	custodial	Yes
FXWLHS2018000282	Odors		Registrar office	environmental	Yes
FXWLHS2018000283	Tight seal on ceiling tiles		125	custodial	Yes
FXWLHS2018000284	General Cleanliness/Dust		142	custodial	Yes
FXWLHS2018000285	Tight seal on ceiling tiles		gym	custodial	Yes
FXWLHS2018000286	Tight seal on ceiling tiles		133	custodial	Yes
FXWLHS2018000287	Miscellaneous finding	Requested more frequent floor cleaning for babies	133		No
FXWLHS2018000289	Tight seal on ceiling tiles		131	custodial	Yes
FXWLHS201800028A	Tight seal on ceiling tiles		Art closet	custodial	Yes
FXWLHS201800028B	Miscellaneous finding	Water stain in light fixture	Art closet		No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLHS201800028C	Tight seal on ceiling tiles		167	custodial	Yes
FXWLHS201800028E	Tight seal on ceiling tiles		155	custodial	Yes
FXWLHS201800028F	Tight seal on ceiling tiles		153	custodial	Yes
FXWLHS2018000291	Tight seal on ceiling tiles		151_hall	custodial	Yes
FXWLHS2018000292	Tight seal on ceiling tiles		Practice 2 in room band room	custodial	Yes
FXWLHS2018000294	Tight seal on ceiling tiles		151	custodial	Yes
FXWLHS2018000295	General Cleanliness/Dust		171	custodial	Yes
FXWLHS2018000296	Tight seal on ceiling tiles	Missing ceiling tiles	307	custodial	Yes
FXWLHS2018000297	Tight seal on ceiling tiles		139	custodial	Yes
FXWLHS201800029B	Windows/Doors open		Stairwells	administration	Yes
FXWLHS201800029C	Tight seal on ceiling tiles		139_office	custodial	Yes
FXWLHS201800029D	Tight seal on ceiling tiles		Main street	custodial	Yes
FXWLHS201800029E	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Small art closet	administration	Yes
FXWLHS201800029F	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		139	administration	Yes
FXWLHS20180002A0	General Cleanliness/Dust		161	custodial	Yes
FXWLHS20180002A1	General Cleanliness/Dust		Theater Booth	custodial	Yes
FXWLHS20180002A2	Tight seal on ceiling tiles		Concessions	custodial	Yes
FXWLHS20180002A3	General Cleanliness/Dust		Elevator	custodial	Yes
FXWLHS20180002A4	Odors		Electrical	environmental	Yes
FXWLHS20180002A5	Tight seal on ceiling tiles		Stairwell to basement	custodial	Yes
FXWLHS20180002A6	Tight seal on ceiling tiles		Hallway in front of gym	custodial	Yes
FXWLHS20180002A7	Tight seal on ceiling tiles		Weight Room storage	custodial	Yes
FXWLHS20180002A8	Tight seal on ceiling tiles	Ceiling tile falling	Weight Room storage	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLHS20180002AA	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		Athletics Office	administration	Yes