

Findings for walkthrough Wilde Lake High School: November 28th, 2018 (WXWLHS20180000AC)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|------------------------------------|------------------|----------------|--------|
| FXWLHS2018000256 | Tight seal on ceiling tiles | | 214 | custodial | Yes |
| FXWLHS2018000257 | Miscellaneous finding | Heavy dust on sprinkler | 218 | | No |
| FXWLHS2018000258 | Miscellaneous finding | Heavy dust on ceiling grids | 218 | | No |
| FXWLHS201800025B | Tight seal on ceiling tiles | | 212 | custodial | Yes |
| FXWLHS201800025C | Miscellaneous finding | Loose supply diffuser | 327 | | No |
| FXWLHS201800025E | General Cleanliness/Dust | | 209 | custodial | Yes |
| FXWLHS201800025F | Tight seal on ceiling tiles | | Outside of 319 | custodial | Yes |
| FXWLHS2018000260 | Tight seal on ceiling tiles | | 226 | custodial | Yes |
| FXWLHS2018000261 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | High dusting | Media | administration | Yes |
| FXWLHS2018000262 | General Cleanliness/Dust | | 217 | custodial | Yes |
| FXWLHS2018000264 | Miscellaneous finding | Need surge protectors | 226 | | No |
| FXWLHS2018000265 | General Cleanliness/Dust | | 211 | custodial | Yes |
| FXWLHS2018000267 | Tight seal on ceiling tiles | | Principal office | custodial | Yes |
| FXWLHS2018000268 | Tight seal on ceiling tiles | | Principal office | custodial | Yes |
| FXWLHS2018000269 | Miscellaneous finding | Need surge protectors | 230 | | No |
| FXWLHS201800026B | Tight seal on ceiling tiles | | Kirchners office | custodial | Yes |
| FXWLHS201800026C | Tight seal on ceiling tiles | | 223 | custodial | Yes |
| FXWLHS201800026D | General Cleanliness/Dust | | 223 | custodial | Yes |
| FXWLHS201800026E | Miscellaneous finding | Need surge protector. Coffee maker | 236 | | No |
| FXWLHS2018000270 | Tight seal on ceiling tiles | | 236 | custodial | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|---|---|-------------------|----------------|--------|
| FXWLHS2018000271 | Tight seal on ceiling tiles | | 238 | custodial | Yes |
| FXWLHS2018000272 | Floor coverings not level or secure (tile, carpets, wood board, etc.) | | cafeteria | building | No |
| FXWLHS2018000273 | Electrical outlets not secured, cover missing, frayed wires on equipment | | cafeteria | building | No |
| FXWLHS2018000274 | Electrical outlets not secured, cover missing, frayed wires on equipment | | cafeteria | building | No |
| FXWLHS2018000275 | Tight seal on ceiling tiles | | 231 | custodial | Yes |
| FXWLHS2018000276 | Tight seal on ceiling tiles | | Cafeteria manager | custodial | Yes |
| FXWLHS2018000279 | Tight seal on ceiling tiles | | Cafeteria manager | custodial | Yes |
| FXWLHS201800027A | Electrical cords unsecured, extend across walkways, cord protectors not installed | | Cafeteria manager | administration | Yes |
| FXWLHS201800027B | Tight seal on ceiling tiles | | Pantry | custodial | Yes |
| FXWLHS201800027C | General Cleanliness/Dust | | Upstairs balcony | custodial | Yes |
| FXWLHS201800027D | Floor coverings not level or secure (tile, carpets, wood board, etc.) | | Staff locker room | building | No |
| FXWLHS201800027E | Tight seal on ceiling tiles | | 123 | custodial | Yes |
| FXWLHS201800027F | Exterior doors not fully sealed (daylight) | | Kitchen | building | No |
| FXWLHS2018000280 | General Cleanliness/Dust | | Hallway | custodial | Yes |
| FXWLHS2018000281 | General Cleanliness/Dust | | Overhang JRT | custodial | Yes |
| FXWLHS2018000282 | Odors | | Registrar office | environmental | Yes |
| FXWLHS2018000283 | Tight seal on ceiling tiles | | 125 | custodial | Yes |
| FXWLHS2018000284 | General Cleanliness/Dust | | 142 | custodial | Yes |
| FXWLHS2018000285 | Tight seal on ceiling tiles | | gym | custodial | Yes |
| FXWLHS2018000286 | Tight seal on ceiling tiles | | 133 | custodial | Yes |
| FXWLHS2018000287 | Miscellaneous finding | Requested more frequent floor cleaning for babies | 133 | | No |
| FXWLHS2018000289 | Tight seal on ceiling tiles | | 131 | custodial | Yes |
| FXWLHS201800028A | Tight seal on ceiling tiles | | Art closet | custodial | Yes |
| FXWLHS201800028B | Miscellaneous finding | Water stain in light fixture | Art closet | | No |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|-----------------------|------------------------------|----------------|--------|
| FXWLHS201800028C | Tight seal on ceiling tiles | | 167 | custodial | Yes |
| FXWLHS201800028E | Tight seal on ceiling tiles | | 155 | custodial | Yes |
| FXWLHS201800028F | Tight seal on ceiling tiles | | 153 | custodial | Yes |
| FXWLHS2018000291 | Tight seal on ceiling tiles | | 151_hall | custodial | Yes |
| FXWLHS2018000292 | Tight seal on ceiling tiles | | Practice 2 in room band room | custodial | Yes |
| FXWLHS2018000294 | Tight seal on ceiling tiles | | 151 | custodial | Yes |
| FXWLHS2018000295 | General Cleanliness/Dust | | 171 | custodial | Yes |
| FXWLHS2018000296 | Tight seal on ceiling tiles | Missing ceiling tiles | 307 | custodial | Yes |
| FXWLHS2018000297 | Tight seal on ceiling tiles | | 139 | custodial | Yes |
| FXWLHS201800029B | Windows/Doors open | | Stairwells | administration | Yes |
| FXWLHS201800029C | Tight seal on ceiling tiles | | 139_office | custodial | Yes |
| FXWLHS201800029D | Tight seal on ceiling tiles | | Main street | custodial | Yes |
| FXWLHS201800029E | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | Small art closet | administration | Yes |
| FXWLHS201800029F | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 139 | administration | Yes |
| FXWLHS20180002A0 | General Cleanliness/Dust | | 161 | custodial | Yes |
| FXWLHS20180002A1 | General Cleanliness/Dust | | Theater Booth | custodial | Yes |
| FXWLHS20180002A2 | Tight seal on ceiling tiles | | Concessions | custodial | Yes |
| FXWLHS20180002A3 | General Cleanliness/Dust | | Elevator | custodial | Yes |
| FXWLHS20180002A4 | Odors | | Electrical | environmental | Yes |
| FXWLHS20180002A5 | Tight seal on ceiling tiles | | Stairwell to basement | custodial | Yes |
| FXWLHS20180002A6 | Tight seal on ceiling tiles | | Hallway in front of gym | custodial | Yes |
| FXWLHS20180002A7 | Tight seal on ceiling tiles | | Weight Room storage | custodial | Yes |
| FXWLHS20180002A8 | Tight seal on ceiling tiles | Ceiling tile falling | Weight Room storage | custodial | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|---|----------|------------------|----------------|--------|
| FXWLHS20180002AA | Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA) | | Athletics Office | administration | Yes |