Findings for walkthrough West Friendship Elementary School: September 21st, 2021 (WXWFES2021000392)

Tracking Number Finding Type Comments Location **Assigned To Closed** Yes

FXWFES2021001F56 Visible mold on surfaces due to elevated relative humidity/dew point Rooms 130, 131, and 134 (storage closet). building