

# Findings for walkthrough Howard High School: November 12th, 2021

## (WXHOHS202100039E)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXHOHS2021001F6A	Visible mold on surfaces due to elevated relative humidity/dew point		Health Room	environmental	Yes
FXHOHS2021001F6C	Visible mold on surfaces due to elevated relative humidity/dew point		Health Room	building	Yes