

Findings for walkthrough Murray Hill Middle School: November 29th, 2018 (WXMHMS20180000AD)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMHMS20180002AC	Elevated moisture per moisture meter	Stained light fixture	Boys restroom	environmental	Yes
FXMHMS20180002AD	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Admin office carpet has stain	Reception area	building	Yes
FXMHMS20180002AE	Odors	Person's perfume	S15	environmental	Yes
FXMHMS20180002AF	Relative humidity above 70%		210	environmental	Yes
FXMHMS20180002B0	Uncomfortable temperature		G3	building	Yes
FXMHMS20180002B2	Tight seal on ceiling tiles	Stained ceiling tiles in kitchen area	cafeteria	custodial	Yes
FXMHMS20180002B5	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Outdoor air vent closed	123	administration	Yes
FXMHMS20180002B6	Tight seal on ceiling tiles	Stained tile in instrument storage room	115	custodial	Yes
FXMHMS20180002B9	Artificial plants/trees	Artificial plant on teacher's desk	115	administration	Yes
FXMHMS20180002BB	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Back room strand of carpet	121	building	Yes
FXMHMS20180002BC	Air freshener/essential oils	Air freshener in office	Cafeteria manager's office	administration	Yes
FXMHMS20180002BD	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Water droplet stains or rust spots on a few diffusers	107	administration	Yes
FXMHMS20180002BF	Elevated moisture per moisture meter	Back right window on right side some mineral salts and blistering paint	106	environmental	Yes
FXMHMS20180002C0	Chemicals are capped	Headphones, instruments, and boxes on floor	116_closet	administration	Yes
FXMHMS20180002C1	Chemicals are capped	Pianos, chairs, boxes improperly stored	Small hall leading to outside	administration	Yes
FXMHMS20180002C2	Miscellaneous finding	Bowed ceiling tile	112		No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMHMS20180002C3	Miscellaneous finding	Bowed ceiling tile	120		No
FXMHMS20180002C4	Chemicals are capped	Pianos, boxes, chairs not properly stored	Small hallway to exit door	administration	Yes
FXMHMS20180002C5	Miscellaneous finding	Bowed ceiling tile really noticeable with lights off	105		No
FXMHMS20180002C7	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Paint coming off of floor	117	building	Yes
FXMHMS20180002C8	Miscellaneous finding	Bowed ceiling tile assume all lower floor same way	104		No
FXMHMS20180002C9	Windows/Doors open	Slightly cracked open	104	administration	Yes
FXMHMS20180002CA	Uncomfortable temperature	Room feels hot and ac/heat unit is noisy	117_office	building	Yes
FXMHMS20180002CB	Uncomfortable temperature	Window cracked open very warm in room teacher made comment of comfort issues	103	building	Yes
FXMHMS20180002CD	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Tear with strands	102	building	Yes
FXMHMS20180002CE	Chemicals are capped	Musical instruments improperly stored, on the floor	Storage closet	administration	Yes
FXMHMS20180002D1	Exterior doors not fully sealed (daylight)	Door without ramp	166	building	Yes
FXMHMS20180002D2	Elevated moisture per moisture meter	Wood ceiling trim towards school end is water stained	166	environmental	Yes
FXMHMS20180002D3	Plumbing fixture leaking/draining slowly	Brown stain towards wall with phone	49	custodial	Yes
FXMHMS20180002D4	Chemicals are capped	Equipment, nets on floor	Locker room storage	administration	Yes
FXMHMS20180002D5	Exterior doors not fully sealed (daylight)	Air gap and hard to open from bottom of stairs door and ramp door rusted through at bottom	49	building	Yes
FXMHMS20180002D7	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Return vent rusty and dirty	49	administration	Yes