

Findings for walkthrough Bryant Woods Elementary School: October 18th, 2022

(WXBWES20220003F0)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXBWES2022001FD9	Air freshener/essential oils	The plug-in odor was strong in rooms 114, portable 113, and portable 118. Portable 118 had at least 3 plug-in odorizers. These devices could mask an odor of concern and/or be an irritant to other individuals.	Rooms 110, 114, portable 113, and portable 118	administration	Yes
FXBWES2022001FDA	Non-issued disinfectants/aerosol sprays	Aerosol air fresheners were present. These products present an airborne irritant when used.	Room 156 and portable 204	administration	Yes
FXBWES2022001FDB	Miscellaneous finding	Food was left within the room and readily accessible to pests and rodents.	Rooms 114 and 156	administration	Yes
FXBWES2022001FDC	Penetrations not sealed	Gaps around/or between conduit penetrating the brick wall.	Exterior of main building across from portable 113	building	Yes
FXBWES2022001FDD	Obstruction(s) to airflow	Room 110 was partially blocking the wall air return grille. Room 112 was completely obstructing the wall air return grille.	Rooms 110 and 112	administration	Yes
FXBWES2022001FDE	Blocked temperature sensors	The room's thermostat is partially obstructed with emergency folder.	Room 114	administration	Yes
FXBWES2022001FDF	Signs of insects or evidence of pest	Does not appear active. Moderate amount of dead insects within the 3 light fixtures.	storage room in cafeteria	custodial	Yes
FXBWES2022001FE0	Stained/damaged tiles	Water stained ceiling tiles. A few in the gym office and cafeteria. Please place a work order for Building Maintenance to address the cause if a work order is not already in progress.	Gym office, cafeteria, and closet in room 129	custodial	Yes
FXBWES2022001FE1	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Visible dust accumulation on supply air diffusers.	Room 136	custodial	Yes
FXBWES2022001FE2	Miscellaneous finding	Floor tile loose and/or popping up.	Gym office	building	Yes
FXBWES2022001FE3	Miscellaneous finding	Textured ceiling surrounding air supply diffusers has visible dust accumulation.	Portable 118	building	Yes
FXBWES2022001FE4	Miscellaneous finding	Floor damaged in corner of room on ramp side (beginning of ramp).	Portable 204	building	Yes