

Findings for walkthrough Bryant Woods Elementary School: October 18th, 2022 (WXBWES20220003F0)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|--|--|----------------|--------|
| FXBWES2022001FD9 | Air freshener/essential oils | The plug-in odor was strong in rooms 114, portable 113, and portable 118. Portable 118 had at least 3 plug-in odorizers. These devices could mask an odor of concern and/or be an irritant to other individuals. | Rooms 110, 114, portable 113, and portable 118 | administration | Yes |
| FXBWES2022001FDA | Non-issued disinfectants/aerosol sprays | Aerosol air fresheners were present. These products present an airborne irritant when used. | Room 156 and portable 204 | administration | Yes |
| FXBWES2022001FDB | Miscellaneous finding | Food was left within the room and readily accessible to pests and rodents. | Rooms 114 and 156 | administration | Yes |
| FXBWES2022001FDC | Penetrations not sealed | Gaps around/or between conduit penetrating the brick wall. | Exterior of main building across from portable 113 | building | Yes |
| FXBWES2022001FDD | Obstruction(s) to airflow | Room 110 was partially blocking the wall air return grille. Room 112 was completely obstructing the wall air return grille. | Rooms 110 and 112 | administration | Yes |
| FXBWES2022001FDE | Blocked temperature sensors | The room's thermostat is partially obstructed with emergency folder. | Room 114 | administration | Yes |
| FXBWES2022001FDF | Signs of insects or evidence of pest | Does not appear active. Moderate amount of dead insects within the 3 light fixtures. | storage room in cafeteria | custodial | Yes |
| FXBWES2022001FE0 | Stained/damaged tiles | Water stained ceiling tiles. A few in the gym office and cafeteria. Please place a work order for Building Maintenance to address the cause if a work order is not already in progress. | Gym office, cafeteria, and closet in room 129 | custodial | Yes |
| FXBWES2022001FE1 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Visible dust accumulation on supply air diffusers. | Room 136 | custodial | Yes |
| FXBWES2022001FE2 | Miscellaneous finding | Floor tile loose and/or popping up. | Gym office | building | Yes |
| FXBWES2022001FE3 | Miscellaneous finding | Textured ceiling surrounding air supply diffusers has visible dust accumulation. | Portable 118 | building | Yes |
| FXBWES2022001FE4 | Miscellaneous finding | Floor damaged in corner of room on ramp side (beginning of ramp). | Portable 204 | building | Yes |