

Findings for walkthrough Applications and Research Laboratory: November 4th, 2022

(WXXARL202200040E)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXARL202200206D	Visible mold on surfaces due to elevated relative humidity/dew point		A16 A/B	building	Yes