

# Findings for walkthrough Wilde Lake Middle School: November 23rd, 2022 (WXWLMS202200041B)

| Tracking Number  | Finding Type   | Comments   | Location                                   | Assigned To | Closed |
|------------------|--|--|--|-------------|--------|
| FXWLMS2022002098 | General Cleanliness/Dust   | The tops of hallway lockers are due for dusting. Visible dust accumulation present. Observed on first floor in hallway between gym / front office and media center. Plus the majority of the second floor. Custodial staff to clean tops of lockers. | Hallways Throughout                        | custodial   | Yes    |
| FXWLMS2022002099 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Visible dust accumulation on air supply diffusers. Custodial staff to clean diffusers.   | Second floor hall outside mechanical room. | custodial   | Yes    |