

Findings for walkthrough Centennial Lane Elementary School: October 14th, 2022 (WXCLES202200041F)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXCLES20220020A6	Visible mold on surfaces due to elevated relative humidity/dew point		auxiliary gym	building	Yes