

# Findings for walkthrough Worthington Elementary School: December 1st, 2022 (WXWOES2022000421)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWOES20220020B8	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct, and replace with new ceiling tile.	Storage closet in room 191 (art)	custodial	Yes
FXWOES20220020B9	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct, and replace with new ceiling tile.	Room 163 (locker area)	custodial	Yes
FXWOES20220020BA	Stained/damaged tiles	Water stained ceiling tiles, especially along perimeter of the exterior wall. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct, and replace with new ceiling tile.	Storage Room 147 (located in foyer of a back exit)	custodial	Yes
FXWOES20220020BB	Signs of insects or evidence of pest	Minor amount (mini snack bag of pretzels) of food readily accessible to pests/rodents. Place food in a durable and sealable container and place in a cabinet. Remind staff about leaving food out that is accessible to pests.	Room 164	administration	Yes
FXWOES20220020BC	Signs of insects or evidence of pest	Food left out in inadequate packaging and readily accessible for pest/rodents. Place food in a durable and sealable container and place in a cabinet. Remind staff about leaving food out that is accessible to pests.	Room 177	administration	Yes
FXWOES20220020BD	Signs of insects or evidence of pest	Food readily accessible to pest/rodents. Place food in a durable and sealable container and place in a cabinet. Remind staff about leaving food out that is accessible to pests.	Room 176	administration	Yes
FXWOES20220020BE	Signs of insects or evidence of pest	Some food readily accessible for pest/rodents while others placed in an appropriate container. Place all food in a durable and sealable container and place in a cabinet. Remind staff about leaving food out that is accessible to pests.	Room 141 A/B	administration	Yes
FXWOES20220020BF	Obstruction(s) to airflow	The two air returns located in the walls were partially obstructed. School administration is to remind and have staff remove and keep the area free of clutter.	Room 141 A/B	administration	Yes
FXWOES20220020C0	Non-issued disinfectants/aerosol sprays	A non-HCPSS cleaning chemical product was present and readily accessible to students. School administration is to inform staff not to bring in non-HCPSS custodial cleaning products. The product is to be removed from the school building.	Room 176	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWOES20220020C1	Non-issued disinfectants/aerosol sprays	An aerosol disinfectant was observed and readily accessible to students. School administration is to remind staff that aerosol disinfectants are not permitted because when used they can become an airborne inhalation irritant to some individuals. The product is to be removed from the school building.	Room 112	administration	Yes
FXWOES20220020C2	Excessive stuffed animals	In a small pop up tent and within the area were several fabric items (pillows, stuffed animal). If items have an educational value, school administration is to ensure staff who brought in the items properly maintains (i.e. periodically launders and/or vacuums) since they can collect allergens over time and when handled/close contact can become an allergen source to those who are sensitive. In addition, the tent allows for less air space for allergens to passively dilute. If they do not serve an educational value, consider removing. Custodial is not responsible for cleaning these items.	Room 163	administration	Yes