

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 13:30	01B. TEMPERATURE: Uncomfortable	Room102 temp inconsistent				39592					
5/11/2017 13:46	01B. TEMPERATURE: Uncomfortable	Room 205	Temperatures hot 80.5 teacher said fan loud			39592					
5/11/2017 13:52	01B. TEMPERATURE: Uncomfortable	410	Too hot in the winter			39592					
5/11/2017 14:05	01B. TEMPERATURE: Uncomfortable	408	Extremely hot AC doesn't seem to be working			39592					
5/11/2017 14:20	01B. TEMPERATURE: Uncomfortable	909	Blocked thermostat	x					5/15/17		
5/11/2017 13:25	02. AIR FRESHENERS	Math storage bathroom		x					5/15/17		
5/11/2017 13:45	02. AIR FRESHENERS	English office bathroom	Spray air freshener	x					5/15/17		
5/11/2017 14:32	02. AIR FRESHENERS	Copy room bathroom	Spray deodorizer	x					5/15/17		
5/11/2017 13:23	03. FOOD: Unsealed, left in room, dirty lunch boxes	FO kitchen	Food items not in sealed box	x					5/15/17		
5/11/2017 13:25	03. FOOD: Unsealed, left in room, dirty lunch boxes	Food not stored in sealed container	FO KITCHEN	x					5/15/17		
5/11/2017 13:53	03. FOOD: Unsealed, left in room, dirty lunch boxes	410	Container	x					5/15/17		
5/11/2017 14:16	03. FOOD: Unsealed, left in room, dirty lunch boxes	912	Container	x					5/15/17		
5/11/2017 14:34	03. FOOD: Unsealed, left in room, dirty lunch boxes	917 Storage	Container	x					5/15/17		
5/11/2017 14:38	03. FOOD: Unsealed, left in room, dirty lunch boxes	905	Container	x					5/15/17		
5/11/2017 14:55	03. FOOD: Unsealed, left in room, dirty lunch boxes	Math/science office	Food not stored in sealed container	x					5/15/17		
5/11/2017 13:13	04: VENTS: Dirty, obstructed (Wall, Ceiling)	702	High dust crew		x				6/30/17		
5/11/2017 13:17	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Stage storage area			x				6/30/17		
5/11/2017 13:19	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Auditorium			x				6/30/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 13:22	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Gym hallway near fire alarm	Faint stain tile		x				6/30/17		
5/11/2017 13:33	04: VENTS: Dirty, obstructed (Wall, Ceiling)	404	Extremely dusty, one needs to be reset		x				6/30/17		
5/11/2017 13:46	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Centennial lane bathrooms vents are dusty and clogged	Vents are dusty and clogged		x				6/30/17		
5/11/2017 13:53	04: VENTS: Dirty, obstructed (Wall, Ceiling)	410	Dusty		x				6/30/17		
5/11/2017 13:58	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Social studies staff lounge bathrooms	Vents need to be opened		x				6/30/17		
5/11/2017 14:02	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Business storage	Dusty		x				6/30/17		
5/11/2017 14:04	04: VENTS: Dirty, obstructed (Wall, Ceiling)	604	Damaged vent near doorway		x						
5/11/2017 14:06	04: VENTS: Dirty, obstructed (Wall, Ceiling)	407	Gross ceiling tiles		x				6/30/17		
5/11/2017 14:14	04: VENTS: Dirty, obstructed (Wall, Ceiling)	912	Dusty		x				6/30/17		
5/11/2017 14:15	04: VENTS: Dirty, obstructed (Wall, Ceiling)	912	Supply extremely noise		x				6/30/17		
5/11/2017 14:22	04: VENTS: Dirty, obstructed (Wall, Ceiling)	909	Loud whistling		x				6/30/17		
5/11/2017 14:30	04: VENTS: Dirty, obstructed (Wall, Ceiling)	907	Dusty		x				6/30/17		
5/11/2017 14:37	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Zaching Lane	Ceiling vent cover not secured		x				6/30/17		
5/11/2017 14:41	04: VENTS: Dirty, obstructed (Wall, Ceiling)	903	Dusty		x				6/30/17		
5/11/2017 14:44	04: VENTS: Dirty, obstructed (Wall, Ceiling)	902	Loud supply noise		x				6/30/17		
5/11/2017 13:27	06: CLEANLINESS: Dust, trash	FO end of hall closet	Floor dusty		x				6/30/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 13:35	06: CLEANLINESS: Dust, trash	103	Minor amount on vent back left of class ceiling		x				6/30/17		
5/11/2017 13:38	06: CLEANLINESS: Dust, trash	Student services kitchen	Dusty floor		x				6/30/17		
5/11/2017 13:42	06: CLEANLINESS: Dust, trash	Centennial Lane	Lockers dusty		x				6/30/17		
5/11/2017 14:00	06: CLEANLINESS: Dust, trash	Business store room	18 inch clearance		x				6/30/17		
5/11/2017 14:16	06: CLEANLINESS: Dust, trash	Wall Street	Lockers dusty		x				6/30/17		
5/11/2017 14:20	06: CLEANLINESS: Dust, trash	909	Excessive clutter, way too much clutter.		x				6/30/17		
5/11/2017 14:40	06: CLEANLINESS: Dust, trash	Zachary Lane	Lockers dusty		x				6/30/17		
5/11/2017 14:56	06: CLEANLINESS: Dust, trash	Science storage	Dusty floor		x				6/30/17		
5/11/2017 13:05	08: CEILING TILES: Stained, broken, holes, painted	Cafe	1 stain tile		x				6/30/17		
5/11/2017 13:06	08: CEILING TILES: Stained, broken, holes, painted	Front office conference room	Cracked ceiling tile		x				6/30/17		
5/11/2017 13:11	08: CEILING TILES: Stained, broken, holes, painted	703 Band room closet	Cracked tile		x				6/30/17		
5/11/2017 13:13	08: CEILING TILES: Stained, broken, holes, painted	702	Stained tile		x				6/30/17		
5/11/2017 13:25	08: CEILING TILES: Stained, broken, holes, painted	401 storage	Stained roof		x				6/30/17		
5/11/2017 13:26	08: CEILING TILES: Stained, broken, holes, painted	Dance studio	2 stained tiles		x				6/30/17		
5/11/2017 13:26	08: CEILING TILES: Stained, broken, holes, painted	Math storage 401 stain and hole			x				6/30/17		
5/11/2017 13:27	08: CEILING TILES: Stained, broken, holes, painted	401	Stained tiles		x				6/30/17		
5/11/2017 13:28	08: CEILING TILES: Stained, broken, holes, painted	402 hole in tiles			x				6/30/17		
5/11/2017 13:29	08: CEILING TILES: Stained, broken, holes, painted	Girls locker room hallway	2 stained tile		x				6/30/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 13:30	08: CEILING TILES: Stained, broken, holes, painted	Boys locker room hallway	Need tiles changed		x				6/30/17		
5/11/2017 13:30	08: CEILING TILES: Stained, broken, holes, painted	403	Painted ceiling tiles		x	18349					
5/11/2017 13:31	08: CEILING TILES: Stained, broken, holes, painted	Student Services	Stained ceiling tile outside data clerk office		x				6/30/17		
5/11/2017 13:32	08: CEILING TILES: Stained, broken, holes, painted	404	Stained, broken and holed		x				6/30/17		
5/11/2017 13:35	08: CEILING TILES: Stained, broken, holes, painted	Escutcheon ring missing on sprinkle head room103			x	39598					
5/11/2017 13:36	08: CEILING TILES: Stained, broken, holes, painted	405	Stains and one is missing in the back storage room		x				6/30/17		
5/11/2017 13:38	08: CEILING TILES: Stained, broken, holes, painted	405	Hole		x				6/30/17		
5/11/2017 13:44	08: CEILING TILES: Stained, broken, holes, painted	Room 105	Holes in ceiling tile by door		x				6/30/17		
5/11/2017 13:48	08: CEILING TILES: Stained, broken, holes, painted	Stained tile, lifted tile	Health room storage closet		x				6/30/17		
5/11/2017 13:49	08: CEILING TILES: Stained, broken, holes, painted	Health suite cot room	Stained tile		x				6/30/17		
5/11/2017 13:51	08: CEILING TILES: Stained, broken, holes, painted	411	A few tiles with holes and some stains		x				6/30/17		
5/11/2017 13:52	08: CEILING TILES: Stained, broken, holes, painted	410	Ceiling tiles are stained, painted, and have holes		x				6/30/17		
5/11/2017 13:54	08: CEILING TILES: Stained, broken, holes, painted	914	Holes		x				6/30/17		
5/11/2017 13:57	08: CEILING TILES: Stained, broken, holes, painted	FO Main Lobby			x				6/30/17		
5/11/2017 14:00	08: CEILING TILES: Stained, broken, holes, painted	202	Coffee pot - side of room. Not being used. 4 ceiling tile small holes	x	x				6/30/17		
5/11/2017 14:03	08: CEILING TILES: Stained, broken, holes, painted	409	Painted ceiling tiles		x	18349					

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 14:04	08: CEILING TILES: Stained, broken, holes, painted	Room 104	Small stain in center of room		x				6/30/17		
5/11/2017 14:07	08: CEILING TILES: Stained, broken, holes, painted	407	Rust of ceiling tiles stained rusty grid		x				6/30/17		
5/11/2017 14:10	08: CEILING TILES: Stained, broken, holes, painted	606	Stained and cracked tiles in rear shop area		x				6/30/17		
5/11/2017 14:11	08: CEILING TILES: Stained, broken, holes, painted	918	HVAC leak		x	39592					
5/11/2017 14:18	08: CEILING TILES: Stained, broken, holes, painted	207	One tile cracked.		x				6/30/17		
5/11/2017 14:21	08: CEILING TILES: Stained, broken, holes, painted	Media Main	stained tile		x				6/30/17		
5/11/2017 14:24	08: CEILING TILES: Stained, broken, holes, painted	Room 209	Small stain middle of room ceiling tiles have been painted by students		x				6/30/17		
5/11/2017 14:25	08: CEILING TILES: Stained, broken, holes, painted	Constitution Avenue social studies storage	massive stains on ceiling tiles		x				6/30/17		
5/11/2017 14:26	08: CEILING TILES: Stained, broken, holes, painted	513	Cracked ceiling tile, front		x				6/30/17		
5/11/2017 14:27	08: CEILING TILES: Stained, broken, holes, painted	Constitution Avenue social studies storage room	18 " clearance		x				6/30/17		
5/11/2017 14:28	08: CEILING TILES: Stained, broken, holes, painted	Photo room	Stained tiles		x				6/30/17		
5/11/2017 14:29	08: CEILING TILES: Stained, broken, holes, painted	907	18" clearance		x				6/30/17		
5/11/2017 14:30	08: CEILING TILES: Stained, broken, holes, painted	210	One ceiling tile with stain		x				6/30/17		
5/11/2017 14:31	08: CEILING TILES: Stained, broken, holes, painted	210	One ceiling tile with stain . . Teac		x				6/30/17		
5/11/2017 14:31	08: CEILING TILES: Stained, broken, holes, painted	917	Holes		x				6/30/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 14:34	08: CEILING TILES: Stained, broken, holes, painted	917 storage	Massive stain on ceiling tile in the store room		x				6/30/17		
5/11/2017 14:35	08: CEILING TILES: Stained, broken, holes, painted	302	2 very small tile holes		x				6/30/17		
5/11/2017 14:36	08: CEILING TILES: Stained, broken, holes, painted	504	Stained ceiling tile		x				6/30/17		
5/11/2017 14:35	08: CEILING TILES: Stained, broken, holes, painted	516	Cracked ceiling tile		x				6/30/17		
5/11/2017 14:47	08: CEILING TILES: Stained, broken, holes, painted	501	Loose tile		x				6/30/17		
5/11/2017 14:48	08: CEILING TILES: Stained, broken, holes, painted	915	18 inch clearance in the closet		x				6/30/17		
5/11/2017 14:52	08: CEILING TILES: Stained, broken, holes, painted	900 esol	One old water mark by vent above teacher's desk		x				6/30/17		
5/11/2017 14:54	08: CEILING TILES: Stained, broken, holes, painted	301	Stained tiles stored at front door to main hall		x				6/30/17		
5/11/2017 15:07	08: CEILING TILES: Stained, broken, holes, painted	Special Ed office conference room	Small holes I ceiling tile		x				6/30/17		
5/11/2017 15:17	08: CEILING TILES: Stained, broken, holes, painted	Art room storage area by kiln	Stained ceiling tile may be active leak						6/30/17		
5/11/2017 15:17	08: CEILING TILES: Stained, broken, holes, painted	Art space	A few old water marks and a few tiles with small holes. Other evaluator marking water mark that might be active						6/30/17		
5/11/2017 13:23	09. WATER DAMAGE: Spotting, mildew, paint irregularities (ceilings, walls, doors, windows)	Indoor concessions				39594					
5/11/2017 13:35	10. CONDENSATION: Evidence of humidity (ceilings, walls, doors, windows)	406	Exterior window			x					
5/11/2017 13:07	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Kitchen office	Fake flowers in vase	x					5/15/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 13:25	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	FO Zehe		x					5/15/17		
5/11/2017 13:28	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	AD office	Remove rug	x					5/15/17		
5/11/2017 13:37	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	405	Fans	x					5/15/17		
5/11/2017 13:39	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	406	Three lamps	x					5/15/17		
5/11/2017 13:40	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	English office	Couch	x					5/15/17		
5/11/2017 13:51	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Health suite cot room	Lamp	x					5/15/17		
5/11/2017 13:57	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Health suite cot room	Lamp	x					5/15/17		
5/11/2017 13:58	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Social Studies staff lounge	College refrigerator	x					5/15/17		
5/11/2017 14:00	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Business store room	Lamps, coffee makers, water cooler, rugs	x					5/15/17		
5/11/2017 14:14	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	912	Refrigerator, lamp	x					5/15/17		
5/11/2017 14:17	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Norris office	3 lamps	x					5/15/17		
5/11/2017 14:18	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Norris office	Fabric chair	x					5/15/17		
5/11/2017 14:19	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	910	Fan coffee maker.	x					5/15/17		
5/11/2017 14:25	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Constitutional Avenue	Refrigerator, lamps	x					5/15/17		
5/11/2017 14:29	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	908	Lamps fabric covered stool, small shelves	x					5/15/17		
5/11/2017 14:33	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	911	Stuffed animal	x					5/15/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 14:34	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	917 Storage	Microwave	x					5/15/17		
5/11/2017 14:38	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	905	Fabric and curtains, coffee maker, small shelves,	x					5/15/17		
5/11/2017 14:40	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	904	Artificial flowers	x					5/15/17		
5/11/2017 14:41	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	903	Lamp, cloth, fan, stool with fabric	x					5/15/17		
5/11/2017 14:45	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Social studies planning room everything	Lamp, artificial flowers	x					5/15/17		
5/11/2017 15:09	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Special Ed office	Microwave and toaster	x					5/15/17		
5/11/2017 13:35	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	Registrars Office	Stuffed animals	x					5/15/17		
5/11/2017 13:36	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	Student Services	Stuffed animals	x					5/15/17		
5/11/2017 14:08	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	Tech office	Heavy black fabric curtain	x					5/15/17		
5/11/2017 14:26	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	Constitution Avenue storage room social studies	Stuffed animals pillows drapes lamps curtains	x					5/15/17		
5/11/2017 14:34	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	Copy room	Filthy couch	x					5/15/17		
5/11/2017 14:46	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	916	Stuffed animals	x					5/15/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 15:01	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	506	Stuffed animals	x					5/15/17		
5/11/2017 14:12	13. AIR GAPS: Structural or physical gaps around exit doors	606	Door in rear shop area			39595					
5/11/2017 14:18	13. AIR GAPS: Structural or physical gaps around exit doors	Wall Street exterior doors	Daylight			39595					
5/11/2017 14:53	13. AIR GAPS: Structural or physical gaps around exit doors	307	Trim ring missing around sprinkler head			39595					
5/11/2017 13:21	14. MATERIALS/CHEMICALS: Improperly stored or marked	Materials stored too close to ceiling	Front office store room	x					5/15/17		
5/11/2017 13:38	14. MATERIALS/CHEMICALS: Improperly stored or marked	405	Spray	x					5/15/17		
5/11/2017 13:38	14. MATERIALS/CHEMICALS: Improperly stored or marked	SS Kitchen		x					5/15/17		
5/11/2017 13:41	14. MATERIALS/CHEMICALS: Improperly stored or marked	406	Windex	x					5/15/17		
5/11/2017 14:03	14. MATERIALS/CHEMICALS: Improperly stored or marked	409	Spray	x					5/15/17		
5/11/2017 14:31	14. MATERIALS/CHEMICALS: Improperly stored or marked	Photo room	Unlabeled/unidentified liquids	x					5/15/17		
5/11/2017 14:37	14. MATERIALS/CHEMICALS: Improperly stored or marked	504	Boxes stored too close to ceiling	x					5/15/17		
5/11/2017 14:51	14. MATERIALS/CHEMICALS: Improperly stored or marked	507	Some items too close ceiling	x					5/15/17		

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 15:00	14. MATERIALS/CHEMICALS: Improperly stored or marked	506	Items stored too close to ceiling	x					5/15/17		
5/11/2017 15:04	14. MATERIALS/CHEMICALS: Improperly stored or marked	505	Lysol	x					5/15/17		
5/11/2017 14:43	15. FLOORS: Coverings not level or secure (tile, carpets, wood board, etc.)	305	Small stains in carpet-floor is level		x				5/15/17		
5/11/2017 14:45	15. FLOORS: Coverings not level or secure (tile, carpets, wood board, etc.)	502	Cracked floor tile near rear lab station		x				5/15/17		
5/11/2017 15:05	17. FISH TANKS: Dirty, near vents/thermostats/electrical outlets	505	Tanks too close to outlets	x					5/15/17		
5/11/2017 13:40	18. PLANTS: NO ARTIFICIAL. LIVE - Waterproof barriers in place	English office	Fake plant	x					5/15/17		
5/11/2017 14:01	18. PLANTS: NO ARTIFICIAL. LIVE - Waterproof barriers in place	Business storage	Flowers	x					5/15/17		
5/11/2017 14:21	18. PLANTS: NO ARTIFICIAL. LIVE - Waterproof barriers in place	Media center	Fake plants	x					5/15/17		
5/11/2017 14:26	18. PLANTS: NO ARTIFICIAL. LIVE - Waterproof barriers in place	Plants	Constitution Avenue	x					5/15/17		
5/11/2017 13:45	19. SINKS AND FOUNTAINS: Drain slowly, work improperly, leak	Centennial lane restrooms	Sinks or not ADA compliant or girls or boys restrooms.			39598					
5/11/2017 14:32	19. SINKS AND FOUNTAINS: Drain slowly, work improperly, leak	Copy room bathroom	Leaky sink			39598					
5/11/2017 14:42	19. SINKS AND FOUNTAINS: Drain slowly, work improperly, leak	Science work room	Leaky faucets			39598					

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 14:22	21. CARPET: Wet near sinks, fountains	Media center	Carpet stains		x				6/30/17		
5/11/2017 14:25	21. CARPET: Wet near sinks, fountains	513	Carpet stains		x				6/30/17		
5/11/2017 13:22	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	C4	Missing light lens			39610					
5/11/2017 13:55	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	914	Need a cord protector			39610					
5/11/2017 14:02	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	603	String lights			39610					
5/11/2017 14:18	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	910	Need cord protector			39610					
5/11/2017 13:15	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	701				39610					
5/11/2017 13:25	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	401	Protector			39610					
5/11/2017 13:25	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	402	Protector			39610					
5/11/2017 13:31	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	403	Needs cord protector			39610					
5/11/2017 13:34	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	404	Needs cord protector			39610					

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 13:54	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	204	Cord to projector always out ... But sub in class and not sure what perm teacher does			39610					
5/11/2017 14:02	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	409	Protector			39610					
5/11/2017 14:05	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	408	Protector			39610					
5/11/2017 14:07	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	407	Protector			39610					
5/11/2017 14:15	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	912	Needs cord protector			39610					
5/11/2017 14:38	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	303	Cords and clutter			39610					
5/11/2017 14:39	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	905	Need cord protector			39610					
5/11/2017 14:41	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	903	Protector			39610					
5/11/2017 14:42	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	902	Cordprotector			39610					
5/11/2017 14:51	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	507	Cord across ceiling			39610					

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 15:02	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	901	Projector cord front of class			39610					
5/11/2017 14:19	25. EXTENSION CORDS: Used as permanent wiring	Tv studio	Needs cord protector			39610					
5/11/2017 13:41	26. ELECTRICAL EQUIPMENT: Near sinks or source of water	406	Clearance of 3 feet for electric panels	x	x				6/30/17		
5/11/2017 13:48	26. ELECTRICAL EQUIPMENT: Near sinks or source of water	Electrical PEMDA	3' clearance	x	x				6/30/17		
5/11/2017 14:23	26. ELECTRICAL EQUIPMENT: Near sinks or source of water	Constitution Avenue electrical room	Clean up clutter for access to electrical panel	x	x				5/15/17		
5/11/2017 13:32	31. VENTS/WINDOWS: Blocked, shrubby near vents or windows which hinder operation	Student Services conference room	Loud vent in ceiling		x	39592					
5/11/2017 13:33	31. VENTS/WINDOWS: Blocked, shrubby near vents or windows which hinder operation	Loud ceiling vent	Data clerk office		x	39592					
5/11/2017 13:35	31. VENTS/WINDOWS: Blocked, shrubby near vents or windows which hinder operation	Registrars office	Loud ceiling vent		x	39592					
5/11/2017 14:35	33. WINDOWS: Broken	504	Broken window			39595					
5/11/2017 14:38	33. WINDOWS: Broken	504	Leak where green house joins ceiling			39595					
5/11/2017 14:41	36. WATER: Standing/stagnant pools	503	No drain for eye wash			39598					
5/11/2017 13:33	39. GUTTERS/DOWNSPOUTS: Not clear or working properly, damaged, missing	SS EM									
5/11/2017 14:43		305	Wall by movie screen needs painted touched up	xxx		39594					
5/11/2017 13:42		Electrical room by 105	Clearance in front of panels storage to high on shelving	xxx					6/30/17		
5/11/2017 14:02		Room 201	Escutcheon ring missing			39598					
5/11/2017 13:35		405	Needs cord protector			39610					

	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDER NUMBER	IEQ WORK ORDER NUMBER	SCHOOL DUDE ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/11/2017 13:56		203	Load fan. Hard to talk over and hear "quiet" students			39592					
5/11/2017 14:13		Room 206	Escutcheon ring missing from sprinkler head			39598					
5/11/2017 14:27		209	Trim ring on sprinkler head falling off			39598					
5/11/2017 14:33		210	Teacher not present... Computer cord in front of desk. Not sure if always out. Could get cover or go behind desk		x	39610					
5/11/2017 14:57		Weight room	Paint needs to be touched up where mirror was removed			39594					