

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 9:55:18	01A. ODOR: Unusual or offensive	111	Stained floor, metal shelves with chemicals rusty				WOID31122	5/15/17			
5/15/2017 9:24:45	01B. TEMPERATURE: Uncomfortable	2	Inconsistent temperature				WOID31121	5/15/17			
5/15/2017 9:27:36	01B. TEMPERATURE: Uncomfortable	3	Temp runs warm, glow in the dark stars on ceiling				WOID31121	5/15/17			
5/15/2017 9:36:16	01B. TEMPERATURE: Uncomfortable	12	Extremely warm				WOID 31113	5/15/17			
5/15/2017 9:49:22	01B. TEMPERATURE: Uncomfortable	26	Unit is pushing hot and cold room is warm. Grill missing and filter needs set.				WOID 31113	5/15/17			
5/15/2017 9:42:13	02. AIR FRESHENERS	42	Fabreeze	X							
5/15/2017 9:42:41	02. AIR FRESHENERS	79 rest room	Air freshener present	X							
5/15/2017 9:42:00	02. AIR FRESHENERS	Admin bathroom	Perfume, hair spray	X							
5/15/2017 9:18:49	03. FOOD: Unsealed, left in room, dirty lunch boxes	8	Container	X							
5/15/2017 9:45:25	03. FOOD: Unsealed, left in room, dirty lunch boxes	50	Toaster oven	X							
5/15/2017 9:45:54	03. FOOD: Unsealed, left in room, dirty lunch boxes	50	Loose food in cabinets	X							
5/15/2017 10:10:5	03. FOOD: Unsealed, left in room, dirty lunch boxes	Room 14	Need container	X							
5/15/2017 9:50:36	03. FOOD: Unsealed, left in room, dirty lunch boxes	Room 28	Needs container	X							
5/15/2017 9:17:38	04: VENTS: Dirty, obstructed (Wall, Ceiling)	8	Wall unit needs floor grill set and filter adjusted				WOID 31117	5/15/17			
5/15/2017 9:38:34	04: VENTS: Dirty, obstructed (Wall, Ceiling)	12	Wall vent missing grill and needs filter adjustment				WOID 31117	5/15/17			
5/15/2017 10:14:2	04: VENTS: Dirty, obstructed (Wall, Ceiling)	15	Grill missing on wall vent and filter needs set				WOID 31117	5/15/17			
5/15/2017 10:16:5	04: VENTS: Dirty, obstructed (Wall, Ceiling)	16	Grill missing and filter needs set				WOID 31117	5/15/17			
5/15/2017 10:24:2	04: VENTS: Dirty, obstructed (Wall, Ceiling)	19	Wall vent needs grill set				WOID 31117	5/15/17			
5/15/2017 9:51:07	04: VENTS: Dirty, obstructed (Wall, Ceiling)	29	Dusty and dirty				WOID 31117	5/15/17			
5/15/2017 9:59:52	04: VENTS: Dirty, obstructed (Wall, Ceiling)	35	Wall vent grill missing and filter needs set				WOID 31117	5/15/17			
5/15/2017 9:43:13	04: VENTS: Dirty, obstructed (Wall, Ceiling)	40					WOID 31117	5/15/17			
5/15/2017 9:43:34	04: VENTS: Dirty, obstructed (Wall, Ceiling)	41	Ceiling vent				WOID 31117	5/15/17			
5/15/2017 9:37:22	04: VENTS: Dirty, obstructed (Wall, Ceiling)	52	Ceiling vents				WOID 31117	5/15/17			
5/15/2017 9:39:36	04: VENTS: Dirty, obstructed (Wall, Ceiling)	52	Nasty				WOID 31117	5/15/17			
5/15/2017 9:18:30	04: VENTS: Dirty, obstructed (Wall, Ceiling)	63					WOID 31117	5/15/17			
5/15/2017 9:16:07	04: VENTS: Dirty, obstructed (Wall, Ceiling)	64	High dust ceiling vents				WOID 31117	5/15/17			

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 9:26:36	04: VENTS: Dirty, obstructed (Wall, Ceiling)	68	Dusty vents				WOID 31117	5/15/17			
5/15/2017 9:09:14	04: VENTS: Dirty, obstructed (Wall, Ceiling)	69	High dust ceiling vents				WOID 31117	5/15/17			
5/15/2017 9:14:08	04: VENTS: Dirty, obstructed (Wall, Ceiling)	73	High dust ceiling vents				WOID 31117	5/15/17			
5/15/2017 9:47:51	04: VENTS: Dirty, obstructed (Wall, Ceiling)	78	Vent above door covered in dust				WOID 31117	5/15/17			
5/15/2017 9:07:01	04: VENTS: Dirty, obstructed (Wall, Ceiling)	88	Ceiling vents need cleaned:				WOID 31117	5/15/17			
5/15/2017 9:42:43	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Custodial 2nd floor across teacher planning 2	Vent is falling dirty				WOID 31117	5/15/17			
5/15/2017 9:43:38	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Restroom teacher planning 2	Vents Dusty and ducts closed				WOID 31117	5/15/17			
5/15/2017 10:08:4	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Restrooms both across from 31	Closed and dirty				WOID 31117	5/15/17			
5/15/2017 9:12:04	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Stairwell by room 7	Vents rusty				WOID 31117	5/15/17			
5/15/2017 9:29:51	04: VENTS: Dirty, obstructed (Wall, Ceiling)	Telecom closet off 59	Dusty ceiling vent				WOID 31117	5/15/17			
5/15/2017 10:19:4	06: CLEANLINESS: Dust, trash	17	Clutter, dusty				WOID 31119	5/15/17			
5/15/2017 9:22:41	06: CLEANLINESS: Dust, trash	59	Dust every surface				WOID 31119	5/15/17			
5/15/2017 9:22:14	06: CLEANLINESS: Dust, trash	60	Low dust high cobwebs				WOID 31119	5/15/17			
5/15/2017 9:21:03	06: CLEANLINESS: Dust, trash	62	Ceiling vents				WOID 31119	5/15/17			
5/15/2017 9:48:28	06: CLEANLINESS: Dust, trash	77	Open boxes, dust, items scattered and everywhere				WOID 31119	5/15/17			
5/15/2017 9:38:00	06: CLEANLINESS: Dust, trash	86	Curtains need dusted/cleaned. Ceiling where stage door closes stained				WOID 31119	5/15/17			
5/15/2017 9:22:52	06: CLEANLINESS: Dust, trash	89	Needs organization and cleaned.				WOID 31119	5/15/17			
5/15/2017 9:23:23	06: CLEANLINESS: Dust, trash	91	Growth on right hand side of closet				WOID 31119	5/15/17			
5/15/2017 9:20:35	06: CLEANLINESS: Dust, trash	92	Floor near exterior doors				WOID 31119	5/15/17			
5/15/2017 10:05:3	06: CLEANLINESS: Dust, trash	98	Clutter on countertops				WOID 31119	5/15/17			
5/15/2017 10:04:2	06: CLEANLINESS: Dust, trash	100	Lots of materials/ art room storage				WOID 31119	5/15/17			
5/15/2017 9:04:07	06: CLEANLINESS: Dust, trash	101					WOID 31119	5/15/17			
5/15/2017 9:16:13	06: CLEANLINESS: Dust, trash	102	Artificial plants, lots of clutter. Multiple cords and powers strips				WOID 31119	5/15/17			
5/15/2017 9:13:30	06: CLEANLINESS: Dust, trash	104	Clutter; ceiling violation; artificial plants; exposed wires/cords				WOID 31119	5/15/17			

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 9:11:53	06: CLEANLINESS: Dust, trash	105	Lots of clutter, boxes stacked up. Wires, cords not maintained.				WOID 31119	5/15/17			
5/15/2017 9:45:17	06: CLEANLINESS: Dust, trash	116	Clutter; dusty; open food				WOID 31119	5/15/17			
5/15/2017 9:35:32	06: CLEANLINESS: Dust, trash	119					WOID 31119	5/15/17			
5/15/2017 10:06:4	06: CLEANLINESS: Dust, trash	2nd floor all lockers	Dusty				WOID 31119	5/15/17			
5/15/2017 9:51:29	06: CLEANLINESS: Dust, trash	Front stairway	Dusty window sills				WOID 31119	5/15/17			
5/15/2017 9:12:43	06: CLEANLINESS: Dust, trash	Hallway Room 7 to stairs	Dusty				WOID 31119	5/15/17			
5/15/2017 9:30:26	06: CLEANLINESS: Dust, trash	Room 10	Dusty				WOID 31119	5/15/17			
5/15/2017 10:09:3	06: CLEANLINESS: Dust, trash	Room 13	Dusty				WOID 31119	5/15/17			
5/15/2017 10:16:0	06: CLEANLINESS: Dust, trash	Room 16	Dusty				WOID 31119	5/15/17			
5/15/2017 10:21:0	06: CLEANLINESS: Dust, trash	Room 18	Clutter				WOID 31119	5/15/17			
5/15/2017 10:23:5	06: CLEANLINESS: Dust, trash	Room 19	Dusty				WOID 31119	5/15/17			
5/15/2017 9:13:24	06: CLEANLINESS: Dust, trash	Room 7 hallway	Dusty				WOID 31119	5/15/17			
5/15/2017 9:29:20	06: CLEANLINESS: Dust, trash	Room 9	Dusty				WOID 31119	5/15/17			
5/15/2017 10:10:0	06: CLEANLINESS: Dust, trash	School store	School store shelves				WOID 31119	5/15/17			
5/15/2017 9:40:04	06: CLEANLINESS: Dust, trash	Seminar 2	Dusty				WOID 31119	5/15/17			
5/15/2017 9:50:09	06: CLEANLINESS: Dust, trash	Tech Ed hallway -/Cafe	Dust around ceiling tiles/sprinklers				WOID 31119	5/15/17			
5/15/2017 9:51:33	06: CLEANLINESS: Dust, trash	6	unidentifiable black substance behind soap dispenser				WOID31132	5/15/17			
5/16/2017 9:49:53	06: CLEANLINESS: Dust, trash	Tech lab room middle	Items stacked to ceiling on left back wall								
5/16/2017 9:56:51	06: CLEANLINESS: Dust, trash	Instrument room behind	Instruments stacked too high								
5/16/2017 9:58:15	06: CLEANLINESS: Dust, trash	Chorus storage room on	Stacked too high								
5/16/2017 10:00:5	06: CLEANLINESS: Dust, trash	Parks rec room	1 mirror has small crack								
5/15/2017 9:55:33	08: CEILING TILES: Stained, broken, holes, painted	37	Escutcheon needs set				WOID31126	5/15/17			
5/15/2017 9:28:03	08: CEILING TILES: Stained, broken, holes, painted	87	1 dislodged and sprinkler head major dust				WOID31126	5/15/17			
5/15/2017 9:13:03	08: CEILING TILES: Stained, broken, holes, painted	Hallway outside choral room	Missing cap for sprinkler head				WOID31126	5/15/17			

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 9:17:27	08: CEILING TILES: Stained, broken, holes, painted	63	One tile stained				WOID31124	5/15/17			
5/15/2017 9:26:08	08: CEILING TILES: Stained, broken, holes, painted	68	Stained ceiling tile				WOID31124	5/15/17			
5/15/2017 9:40:18	08: CEILING TILES: Stained, broken, holes, painted	81	Multiple stained tiles				WOID31124	5/15/17			
5/15/2017 9:49:21	08: CEILING TILES: Stained, broken, holes, painted	112					WOID31124	5/15/17			
5/15/2017 9:48:28	08: CEILING TILES: Stained, broken, holes, painted	113					WOID31124	5/15/17			
5/15/2017 10:10:1	08: CEILING TILES: Stained, broken, holes, painted	125					WOID31124	5/15/17			
5/15/2017 9:25:01	08: CEILING TILES: Stained, broken, holes, painted	23 and storage	Stained and suspicious potential mold				WOID31124	5/15/17			
5/15/2017 9:43:18	08: CEILING TILES: Stained, broken, holes, painted	Loading area hallway					WOID31124	5/15/17			
5/15/2017 10:31:0	08: CEILING TILES: Stained, broken, holes, painted	Hallway to stairwells from 20	Stained				WOID31124	5/15/17			
5/15/2017 9:32:25	08: CEILING TILES: Stained, broken, holes, painted	Locker 667	Stained tile				WOID31124	5/15/17			
5/15/2017 9:58:34	08: CEILING TILES: Stained, broken, holes, painted	Room 34	Several tiles stained				WOID31124	5/15/17			
5/15/2017 10:00:4	08: CEILING TILES: Stained, broken, holes, painted	Room 34	Several tiles stained				WOID31124	5/15/17			
5/15/2017 10:29:4	08: CEILING TILES: Stained, broken, holes, painted	Stairwell by room 20	Stained tile				WOID31124	5/15/17			
5/15/2017 9:11:15	08: CEILING TILES: Stained, broken, holes, painted	Stairwell Room 7	Stained and painted tile				WOID31124	5/15/17			
5/15/2017 9:50:39	08: CEILING TILES: Stained, broken, holes, painted	PE/Cafe corridor					WOID31125	5/15/17			
5/15/2017 9:29:49	08: CEILING TILES: Stained, broken, holes, painted	122	Faint water marks on ceiling tile				WOID31125	5/15/17			
5/15/2017 9:20:11	08: CEILING TILES: Stained, broken, holes, painted	22	18" clearance	X							

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 9:35:39	08: CEILING TILES: Stained, broken, holes, painted	54	Ceiling clearance	X							
5/15/2017 9:11:27	08: CEILING TILES: Stained, broken, holes, painted	72	Clearance from ceiling	X							
5/15/2017 9:24:23	08: CEILING TILES: Stained, broken, holes, painted	75	Ceiling clearance	X							
5/15/2017 9:07:39	08: CEILING TILES: Stained, broken, holes, painted	76	Clearance for sprinkler, dust	X							
5/15/2017 9:24:36	08: CEILING TILES: Stained, broken, holes, painted	76	Clearance	X							
5/15/2017 9:47:51	08: CEILING TILES: Stained, broken, holes, painted	Room 27	18" storage room	X							
5/15/2017 9:16:48	08: CEILING TILES: Stained, broken, holes, painted	Room 8	18 inch hang paper clip	X							
5/16/2017 9:45:22	08: CEILING TILES: Stained, broken, holes, painted	Storage next to custodial	Toward back on left								
5/15/2017 11:40:1	10. CONDENSATION: Evidence of humidity (ceilings, walls, doors, windows)	Stairwell next to 117	Broken seal				WOID31127	5/15/17			
5/15/2017 9:44:22	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	114	Items to close to ceiling	X							
5/15/2017 9:31:40	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	10	Shelf, lamp,	X							
5/15/2017 9:35:54	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	12	Fan	X							
5/15/2017 10:09:5	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	13	Shelves	X							
5/15/2017 10:11:1	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	14	Lamp, shelves	X							
5/15/2017 10:17:2	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	16	Shelves	X							
5/15/2017 10:22:4	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	18	Lamp, shelves,	X							
5/15/2017 10:23:5	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	19	Fan	X							

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 10:27:2	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	20	Lamp	X							
5/15/2017 9:23:06	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	23	Lamp and shelf	X							
5/15/2017 9:45:33	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	40	Fans, fridge	X							
5/15/2017 9:40:58	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	44	Fridge, fan, fabric	X							
5/15/2017 9:47:53	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	47	Lamp microwave	X							
5/15/2017 9:38:20	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	51	Christmas lights	X							
5/15/2017 9:34:39	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	53	Lamp, fan	X							
5/15/2017 9:33:40	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	55	Lamp	X							
5/15/2017 9:32:17	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	57	String lights. Small fans	X							
5/15/2017 9:32:39	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	57	Stools	X							
5/15/2017 9:22:06	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	61	Lamp, fan in 59	X							
5/15/2017 9:26:14	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	66	Fan	X							
5/15/2017 9:57:03	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	109	Coffee maker, mini fridge	X							
5/15/2017 10:14:2	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	127	Microwave, mini fridge	X							
5/15/2017 10:13:0	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	128	Fabric coverings on lights	X							
5/15/2017 9:25:57	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	23 storage	Refrigerator and microwave	X							
5/15/2017 9:10:52	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Refrigerator microwave in closet		X							

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 10:14:3	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Room 15	Standing portable fan	X							
5/15/2017 9:55:00	11. NON-ISSUED HCPSS FURNITURE AND APPLIANCES	Room 36	Microwave and edible food in fridge	X							
5/15/2017 9:25:07	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	1	Artificial plants	X							
5/15/2017 10:20:1	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	17	Wall hangings	X							
5/15/2017 10:21:2	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	18	Wall hangings and table cloth	X							
5/15/2017 9:57:47	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	20	Electric lights; valances; fabric coverings	X							
5/15/2017 9:48:30	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	47	Stuffed animals	X							
5/15/2017 9:37:10	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	51	Material on wall, carpet	X							
5/15/2017 9:38:47	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	51	Stuffed animals	X							
5/15/2017 9:32:16	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	58	Pillows	X							
5/15/2017 9:19:37	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	106	Dusty; cluttered; extensive decorations stored on open shelves	X							
5/15/2017 9:21:00	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	107	Dusty floors, stained ceiling tiles, stain on wall looks like something leaked from above.	X							
5/15/2017 9:36:51	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	120	Dusty; food (sugar, tenderizer, oil, salt) not in sealed containers	X							
5/15/2017 10:13:1	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	126	Material seats; bean bags; newspaper on wall	X							
5/15/2017 9:05:58	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	67 home ec	Curtains	X							
5/15/2017 9:39:47	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	117	Cloth background on bulletin boards, dusty floors	X							
5/15/2017 9:36:05	12. FABRIC MATERIALS: Stuffed animals, beanbags, pillows, blankets, rugs, etc.	Room 12	Rug	X							

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 10:21:4	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	51	Major concern with heating along the floor, major damage				WOID31133 / WOID31221				
5/15/2017 9:19:30	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	59	Electrical roughed box with no cap/cover				WOID31133				
5/15/2017 10:19:3	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	Room 17	Need cord protector				WOID31133				
5/15/2017 9:49:30	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	Room 26	Floor covers need				WOID31133				
5/15/2017 10:05:0	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	Room 33	Need cord protector				WOID31133				
5/15/2017 9:39:28	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	Seminar 2	Need cord protector				WOID31133				
5/15/2017 10:03:0	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	Stairwell by 33	Lens need set in fixture				WOID31133				
5/15/2017 9:33:36	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	121	Moisture/ dirt in light fixture; clutter on lab stations				WOID31133				
5/15/2017 9:51:33	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	6	Filter falls out of furnace unit				WOID31133 / WOID31221				
5/15/2017 9:28:03	23. ELECTRICAL: Electrical outlets not secured, cover missing, frayed wires on equipment	9	Floor outlets need covers				WOID31136				
5/15/2017 9:13:45	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	7	Protector				WOID31133				
5/15/2017 9:31:09	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	Room 10	Cord protector				WOID31133				
5/15/2017 9:34:45	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	Room 12	Need cord protector				WOID31133				

EMMS IEQ Walkthrough Summary Spring 2017 - Room Observations (Responses)

Timestamp	Observation:	Room Number or Location/Name:	Comments for this room:	ADMINISTRATION	CUSTODIAL	FACILITIES WORK ORDERS	IEQ WORK ORDERS	ASSIGNED DATE	COMPLETION DATE	30-DAY REVISIT	CLOSED
5/15/2017 9:27:43	24. ELECTRICAL CORDS: Unsecured, extend across walkways, cord protectors not installed	Room 9	Cord protector				WOID31133				
5/15/2017 9:34:23	26. ELECTRICAL EQUIPMENT: Near sinks or source of water	82	Lights near employee bathroom dis colored not on				WOID31133				
5/15/2017 9:46:02	31. VENTS/WINDOWS: Blocked, shrubbery near vents or windows which hinder operation	46		X							
5/15/2017 10:14:4	31. VENTS/WINDOWS: Blocked, shrubbery near vents or windows which hinder operation	49		X							
5/15/2017 11:39:1	34. WINDOWS: Open	82	Needs closed	X							
5/15/2017 11:40:5	37. EXTERIOR VENEER: Exterior wall damaged	Outside 112	Mortar missing				WOID31135				
5/15/2017 9:17:21		64	General rustiness from woodshop								
5/15/2017 9:31:34		83	Boxes stored too close to ceiling	X							
5/15/2017 9:33:40		84	Storage too close to ceiling	X							
5/15/2017 9:17:01		95	Clothes closet boxes too close to ceiling	X							
5/15/2017 9:44:10		79 rest room	Boxes close to ceiling in shower	X							
5/15/2017 9:32:58		82	Wooden mouse trap out	X							