



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

EMSL Order: 371921258
Customer ID: WATE78
Customer PO:
Project ID:

Attention: Eric Messerschmidt
WaterPro, Inc.
5690 French Avenue
Sykesville, MD 21784

Phone: (410) 746-1111
Fax: (410) 551-6053
Collected Date: 09/19/2019 08:05 AM - 09/19/2019 11:15 AM
Received Date: 09/20/2019 10:45 AM
Processed Date: 09/21/2019 12:00 PM
Analyzed Date: 10/03/2019 08:00 AM

Project: HCPB Summer (Howard County)

Legionella Detection - Presumptive ID by CDC Culture Method (EMSL Method M210)

Client Sample ID/Sample Location Lab Sample Number	Sample Type	Volume Submitted (mL)	Volume Filtered (mL)	Method Processed	Identification	Volume Examined (mL)	Limit of Detection (CFU/mL)	Final Results (CFU/mL)
22 - Hammond HS 371921258-0001	Non-potable	100	NA	Direct Plate (Acid)	Legionella spp.	0.05	20.00	60.00
23 - Reservoir HS 371921258-0002	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
24 - Laurel Woods ES 371921258-0003	Non-potable	100	NA	Direct Plate (Acid)	Legionella spp.	0.05	20.00	40.00
25 - Forest Ridge ES 371921258-0004	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND

Vincent Iuzzolino, M.S., Laboratory Director
or other approved signatory

Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial report from: 10/04/2019 12:35 PM

Printed 10/04/2019 12:35 PM