



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
634702-1	TRES 1A First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Kitchen, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.3 ug/L	
634702-2	TRES 1B Flush	03/23/2022 5:48 am	Faucet, Cold, Consumption, Kitchen, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-3	TRES 2 First-Draw	03/22/2022 5:05 am	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Cafeteria, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	
634702-4	TRES 3 First-Draw	03/22/2022 5:05 am	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-5	TRES 3BW First-Draw	03/23/2022 5:48 am	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Hallway, , Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-6	TRES 4 First-Draw	03/22/2022 5:05 am	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-7	TRES 5F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
634702-8	TRES 5S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.9 ug/L	
634702-9	TRES 6F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
634702-10	TRES 6S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.5 ug/L	0.50 ug/L.
634702-11	TRES 7F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	4.1 ug/L	
634702-12	TRES 7S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.7 ug/L	
634702-13	TRES 8 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3 ug/L	3.0 ug/L.
634702-14	TRES 9F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.4 ug/L	



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
634702-15	TRES 9S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.5 ug/L	
634702-16	TRES 10F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
634702-17	TRES 10S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.61 ug/L	
634702-18	TRES 11 First-Draw	03/22/2022 5:05 am	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-19	TRES 12F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	14 ug/L	13.6 ug/L. This result meets or exceeds the 5.5ppb action level as established by MDE for schools.
634702-20	TRES 12S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.76 ug/L	
634702-21	TRES 13 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Media Center, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2 ug/L	2.0 ug/L.
634702-22	TRES 14F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.52 ug/L	
634702-23	TRES 14S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-24	TRES 15F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-25	TRES 15S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
634702-26	TRES 16 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	
634702-27	TRES 17F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
634702-28	TRES 17S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.71 ug/L	
634702-29	TRES 18F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2 ug/L	2.0 ug/L.
634702-30	TRES 18S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-31	TRES 19F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.8 ug/L	
634702-32	TRES 19S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.96 ug/L	
634702-35	TRES 20F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	5.8 ug/L	This result meets or exceeds the 5.5ppb action level as established by MDE for schools.
634702-36	TRES 20S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-37	TRES 21F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1 ug/L	1.0 ug/L.
634702-38	TRES 21S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.71 ug/L	



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
634702-39	TRES 22 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.3 ug/L	
634702-40	TRES 23F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	6.1 ug/L	This result meets or exceeds the 5.5ppb action level as established by MDE for schools.
634702-41	TRES 23S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.4 ug/L	
634702-42	TRES 24F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.8 ug/L	
634702-43	TRES 24S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.79 ug/L	
634702-44	TRES 25F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2 ug/L	2.0 ug/L.
634702-45	TRES 25S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
634702-46	TRES 26 First-Draw	03/22/2022 5:05 am	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.54 ug/L	
634702-47	TRES 27F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.86 ug/L	
634702-48	TRES 27S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.79 ug/L	
634702-49	TRES 28F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
634702-50	TRES 28S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.78 ug/L	
634702-51	TRES 29 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.1 ug/L	
634702-52	TRES 30F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
634702-53	TRES 30S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.86 ug/L	
634702-54	TRES 31F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.8 ug/L	
634702-55	TRES 31S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.51 ug/L	
634702-56	TRES 32F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	14 ug/L	13.9 ug/L. This result meets or exceeds the 5.5ppb action level as established by MDE for schools.
634702-57	TRES 32S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.56 ug/L	
634702-58	TRES 33F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.1 ug/L	
634702-59	TRES 33S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	
634702-60	TRES 34F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3 ug/L	3.0 ug/L.



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
634702-61	TRES 34S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.97 ug/L	
634702-62	TRES 35 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.2 ug/L	
634702-63	TRES 36F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.3 ug/L	
634702-64	TRES 36S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	
634702-65	TRES 37F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	4.4 ug/L	
634702-66	TRES 37S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.69 ug/L	
634702-67	TRES 38 First-Draw	03/22/2022 5:05 am	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.3 ug/L	
634702-68	TRES 40S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.66 ug/L	
634702-69	TRES 41 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	4.2 ug/L	
634702-70	TRES 42F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.76 ug/L	
634702-71	TRES 42S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.9 ug/L	
634702-72	TRES 43F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.6 ug/L	0.60 ug/L.
634702-73	TRES 43S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.5 ug/L	
634702-74	TRES 44F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.58 ug/L	



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
634702-75	TRES 44S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.3 ug/L	
634702-76	TRES 45 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	4.3 ug/L	
634702-77	TRES 46F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.5 ug/L	
634702-78	TRES 46S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.59 ug/L	
634702-79	TRES 47F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.4 ug/L	
634702-80	TRES 47S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.62 ug/L	
634702-81	TRES 48F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Office, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.2 ug/L	
634702-82	TRES 48S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Office, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.4 ug/L	
634702-83	TRES 49F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.6 ug/L	
634702-84	TRES 49S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Classroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.83 ug/L	
634702-85	TRES 50 First-Draw	03/23/2022 5:48 am	Faucet, Cold, Consumption, Teachers' Lounge/Break Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.4 ug/L	
634702-86	TRES 52F First-Draw	03/22/2022 5:05 am	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Consumption, Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.3 ug/L	
634702-87	TRES 52S First-Draw	03/23/2022 5:48 am	Combination Sink - Faucet, Cold, Consumption, Nurse's Office/Health Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.4 ug/L	



# CERTIFICATE OF ANALYSIS

**Chain of Custody:** 634702  
**Client:** Howard County Public School System  
**Address:** 10910 Route 108  
 Ellicott City, MD 21042  
**Attention:** Jeff Klenk

**Job Name:** Triadelphia Ridge Elementary School  
**Job Location:** 13400 Triadelphia Road, Ellicott City,  
 MD 21042  
**Job Number:** 13.073  
**P.O. Number:** Not Provided

**Date Submitted:** 04/01/2022  
**Date Analyzed:** 04/07/2022  
**Report Date:** 04/08/2022  
**Date Sampled:** 03/22/2022 - 03/23/2022  
**Person Submitting:** Jeff Klenk

## Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Sample Collection Information	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
-------------------	----------------------	-----------	----------	-------------------------------	---------------	----------------	-----------------	--------------	----------

**Analysis Methods:** Flame AA: APHA SM3111B (1999, 22nd Ed.), Furnace AA: APHA SM3113B (2010, 22nd Ed.), ICP: EPA 200.8 (Rev. 5.4)

mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

**Analyst(s):** Jean-Paul Littleton, George Land

**Sample Collector:** Jeff Klenk  
**Certification:**

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

**Technical Director** George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.