

CERTIFICATE OF ANALYSIS

Chain of Custody:	654038	Job Name:	Bellow Springs Elementary School	Date Submitted:	12/22/2023
Client:	Howard County Public School System	Job Location:	8125 Old Stockbridge Drive, Ellicott City, MD 21043	Date Analyzed:	01/22/2024
Address:	10910 Route 108 Ellicott City Maryland 21042	Job Number:	13.078	Report Date:	01/23/2024
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	12/19/2023 - 12/20/2023
				Person Submitting:	John D. Farmer III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
654038-1	1: BSES-1 First Draw	12/20/2023 5:27 AM	Combination Sink - Faucet, Cold, Yes (= Consumption), Kitchen, , Faucet, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.5 ug/L	
654038-2	2: BSES-3 First-Draw	12/20/2023 5:25 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Cafeteria, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-3	3: BSES-3BW First-Draw	12/19/2023 5:37 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Cafeteria, , Bottle Fill, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-4	4: BSES-4 First-Draw	12/20/2023 5:29 AM	Drinking Water Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-5	5: BSES-6 First-Draw	12/20/2023 5:19 AM	Faucet, Cold, Yes (= Consumption), Office, , Faucet, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-6	6: BSES-7 First-Draw	12/20/2023 5:20 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Faucet, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-7	7: BSES-8 First-Draw	12/20/2023 5:21 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Faucet, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-8	8: BSES-9F First-Draw	12/20/2023 5:32 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-9	9: BSES-10F First-Draw	12/20/2023 5:33 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-10	10: BSES-11F First-Draw	12/20/2023 5:34 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-11	11: BSES-12F First-Draw	12/20/2023 5:35 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-12	12: BSES-13F First-Draw	12/20/2023 5:36 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody:	654038	Job Name:	Bellow Springs Elementary School	Date Submitted:	12/22/2023
Client:	Howard County Public School System	Job Location:	8125 Old Stockbridge Drive, Ellicott City, MD 21043	Date Analyzed:	01/22/2024
Address:	10910 Route 108 Ellicott City Maryland 21042	Job Number:	13.078	Report Date:	01/23/2024
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	12/19/2023 - 12/20/2023
				Person Submitting:	John D. Farmer III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
654038-13	13: BSES-14F First-Draw	12/20/2023 5:40 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-14	14: BSES-15 First-Draw	12/20/2023 5:38 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, , Faucet, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-15	15: BSES-16 First-Draw	12/20/2023 5:39 AM	Refrigerator Water Dispenser -- Not required if non-metal water line, Yes (= Consumption), Teachers' Lounge/Break Room, , Dispenser, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-16	16: BSES-17F First-Draw	12/20/2023 5:41 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	2.1 ug/L	
654038-17	17: BSES-18F First-Draw	12/20/2023 5:42 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-18	18: BSES-19 First-Draw	12/20/2023 5:43 AM	Drinking Water Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-19	19: BSES-20F First-Draw	12/20/2023 5:44 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.6 ug/L	
654038-20	20: BSES-21F First-Draw	12/20/2023 5:45 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.7 ug/L	
654038-21	21: BSES-22F First-Draw	12/20/2023 5:46 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.1 ug/L	
654038-22	22: BSES-24F First-Draw	12/20/2023 5:50 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-23	23: BSES-25F First-Draw	12/20/2023 5:50 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-24	24: BSES-27F First-Draw	12/20/2023 5:51 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody:	654038	Job Name:	Bellow Springs Elementary School	Date Submitted:	12/22/2023
Client:	Howard County Public School System	Job Location:	8125 Old Stockbridge Drive, Ellicott City, MD 21043	Date Analyzed:	01/22/2024
Address:	10910 Route 108 Ellicott City Maryland 21042	Job Number:	13.078	Report Date:	01/23/2024
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	12/19/2023 - 12/20/2023
				Person Submitting:	John D. Farmer III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
654038-25	25: BSES-28F First-Draw	12/20/2023 5:51 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-26	26: BSES-29F First-Draw	12/20/2023 5:52 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	2.8 ug/L	
654038-27	27: BSES-30F First-Draw	12/20/2023 5:55 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-28	28: BSES-31F First-Draw	12/20/2023 5:55 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-29	29: BSES-33F First-Draw	12/20/2023 5:56 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-30	30: BSES-34F First-Draw	12/20/2023 5:57 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-31	31: BSES-35F First-Draw	12/20/2023 5:54 AM	Drinking Water Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-32	32: BSES-36F First-Draw	12/20/2023 5:54 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.3 ug/L	
654038-33	33: BSES-39F First-Draw	12/20/2023 6:00 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-34	34: BSES-40F First-Draw	12/20/2023 6:01 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-35	35: BSES-41F First-Draw	12/20/2023 6:03 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	4.8 ug/L	
654038-36	36: BSES-42F First-Draw	12/20/2023 5:58 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.6 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody:	654038	Job Name:	Bellow Springs Elementary School	Date Submitted:	12/22/2023
Client:	Howard County Public School System	Job Location:	8125 Old Stockbridge Drive, Ellicott City, MD 21043	Date Analyzed:	01/22/2024
Address:	10910 Route 108 Ellicott City Maryland 21042	Job Number:	13.078	Report Date:	01/23/2024
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	12/19/2023 - 12/20/2023
				Person Submitting:	John D. Farmer III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
654038-37	37: BSES-43 First-Draw	12/20/2023 6:04 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-38	38: BSES-44F First-Draw	12/20/2023 6:05 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-39	39: BSES-45F First-Draw	12/20/2023 6:06 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-40	40: BSES-50F First-Draw	12/20/2023 6:08 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.2 ug/L	
654038-41	41: BSES-51F First-Draw	12/20/2023 6:08 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-42	42: BSES-54F First-Draw	12/20/2023 6:09 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-43	43: BSES-55F First-Draw	12/20/2023 6:10 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	1.4 ug/L	
654038-44	44: BSES-56F First-Draw	12/20/2023 6:11 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-45	45: BSES-57F First-Draw	12/20/2023 6:12 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-46	46: BSES-59F First-Draw	12/20/2023 6:13 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-47	47: BSES-60F First-Draw	12/20/2023 6:14 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-48	48: BSES-61F First-Draw	12/20/2023 6:16 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	2.3 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody:	654038	Job Name:	Bellow Springs Elementary School	Date Submitted:	12/22/2023
Client:	Howard County Public School System	Job Location:	8125 Old Stockbridge Drive, Ellicott City, MD 21043	Date Analyzed:	01/22/2024
Address:	10910 Route 108 Ellicott City Maryland 21042	Job Number:	13.078	Report Date:	01/23/2024
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	12/19/2023 - 12/20/2023
				Person Submitting:	John D. Farmer III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
654038-49	49: BSES-62F First-Draw	12/20/2023 6:18 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-50	50: BSES-65F First-Draw	12/20/2023 6:20 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-51	51: BSES-66F First-Draw	12/20/2023 6:20 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-52	52: BSES-68 First-Draw	12/20/2023 6:17 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, , Bubblers, Main Bldg, 1st Floor	Furnace AA	Lead	1 ug/L	<1 ug/L	
654038-53	54: BSES-1 Flush	12/20/2023 6:25 AM	Faucet, Cold, Yes (= Consumption), Kitchen, , Faucet, Main Bldg, 1st Floor					VOID: Sample Not Analyzed - Associated 1st Draw <5.5ppb

Analysis Method: APHA SM 3113B (GFAA)
Preparation Method: None
mg/L = Parts Per Million (ppm), N/A = Not Applicable, ug/L = Parts Per Billion, N/P = Not Provided

Sample Collector: Christopher Madden
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Analyst(s): Nida McGarvey



Technical Director George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.



QC Summary for SDG #78705

Overview

Analysis Type: Furnace AA
Sample Type: Lead Water
Analysis Date: 01/22/2024

Samples Included

654038-1, 654038-2, 654038-3, 654038-4, 654038-5, 654038-6, 654038-7, 654038-8, 654038-9, 654038-10, 654038-11, 654038-12, 654038-13, 654038-14, 654038-15, 654038-16, 654038-17, 654038-18, 654038-19, 654038-20

Preparation Blank



Result: 0.000 ppm

Report Limit Verification Sample



Percent Recovery: 122.0 %

Duplicates

RPD: N/A

Matrix Spike Analysis

Spiked Sample Percent Recovery: N/A
Spike Duplicate Percent Recovery: N/A
RPD: N/A

Matrix Blank



Result: 0.000 ppm

Lab Control Sample #1



Percent Recovery: 114.32 %

Lab Control Sample #2



Percent Recovery: 108.26 %

Reference Sample



Percent Recovery: 101.6%

Calibration Curve



Correlation: 0.999933

Serial Dilution / Bench Spike

Serial Dilution RPD: N/A
Bench Spike Percent Recovery: 102.2%

Notes



QC Summary for SDG #78706

Overview

Analysis Type: Furnace AA
Sample Type: Lead Water
Analysis Date: 01/18/2024

Samples Included

654038-21, 654038-22, 654038-23, 654038-24, 654038-25, 654038-26, 654038-27, 654038-28, 654038-29, 654038-30, 654038-31, 654038-32, 654038-33, 654038-34, 654038-35, 654038-36, 654038-37, 654038-38, 654038-39, 654038-40

Preparation Blank



Result: 0.000 ppm

Report Limit Verification Sample



Percent Recovery: 119.0 %

Duplicates

RPD: N/A

Matrix Spike Analysis

Spiked Sample Percent Recovery: N/A
Spike Duplicate Percent Recovery: N/A
RPD: N/A

Matrix Blank



Result: 0.000 ppm

Lab Control Sample #1



Percent Recovery: 105.84 %

Lab Control Sample #2



Percent Recovery: 108.18 %

Reference Sample



Percent Recovery: 108.3%

Calibration Curve



Correlation: 0.999933

Serial Dilution / Bench Spike

Serial Dilution RPD: N/A
Bench Spike Percent Recovery: 97.1%

Notes



QC Summary for SDG #78707

Overview

Analysis Type: Furnace AA
Sample Type: Lead Water
Analysis Date: 01/18/2024

Samples Included

654038-41, 654038-42, 654038-43, 654038-44, 654038-45, 654038-46, 654038-47, 654038-48,
654038-49, 654038-50, 654038-51, 654038-52, 654038-53

Preparation Blank



Result: 0.001 ppm

Report Limit Verification Sample



Percent Recovery: 119.0 %

Duplicates

RPD: N/A

Matrix Spike Analysis

Spiked Sample Percent Recovery: N/A
Spike Duplicate Percent Recovery: N/A
RPD: N/A

Matrix Blank



Result: 0.001 ppm

Lab Control Sample #1



Percent Recovery: 109.36 %

Lab Control Sample #2



Percent Recovery: 115.45 %

Reference Sample



Percent Recovery: 108.3%

Calibration Curve



Correlation: 0.999933

Serial Dilution / Bench Spike

Serial Dilution RPD: N/A
Bench Spike Percent Recovery: 103.8%

Notes



AMA Analytical Services, Inc.

Focused On Results.

E-COC Pb H2O at MD Schools
Howard County Public School System
10910 Clarksville Pike
Ellicott City, MD 21042
(410) 313-6600

COC#: **654038**

School Name: Bellow Springs Elementary School

Address: 8125 Old Stockbridge Drive, Ellicott City, MD 21043

County: Howard County

MSDE ID #: 13.078

Project Manager: Christopher Madden

PM Cell Phone No.: 410-313-8874

Email Results To: christopher_madden@hcpss.org

Email Invoice To: christopher_madden@hcpss.org

Samples Collected by: Christopher Madden

Sampler's Phone Number: 410-313-6699

Sampler's Affiliation: Howard County Public School System

Turn-Around-Time:

5-Day

Due Date & Time:

1/3/2024 5:00 PM

Enter as MM/DD/YYYY HH:MM

Start Date & Time: 12/19/2023 5:37AM & 12/20/2023 5:19AM

Stop Date & Time: 12/19/2023 5:37AM & 12/20/2023 6:25AM

Enter as MM/DD/YYYY HH:MM

Sample Collection Data

NOTES: ONLY ANALYZE FLUSH SAMPLE (#53) IF ASSOCIATED 1ST DRAW SAMPLE (#1) IS > 5.5 PPB

AMA ID	Bottle ID # (Label bottle submitted to lab w/ this ID #)	Outlet ID Code (Unique ID for each Outlet)	Draw Type (First Draw or Flush)	Sample ID for AMA LIMS	Outlet Type (Select from the Drop-Down Options)	Outlet Use (Consumption or Non-Consumption)	Outlet Area Type (Select from Drop-Down Options)	Outlet Location Description (Be as detailed as possible, ie, between Room, 22 & 23)	Outlet Description (Be as detailed as possible, ie, Left or Right)	Building ID (Only required if school has multiple buildings, ie, Main Bldg, Toilet 1)	Building Floor (Use "1" if Bldg is single floor)	Sample Location for AMA LIMS	Date Collected (MM/DD/YYYY)	Time Collected (Military time, ie, 08:00 or 16:00)	Collection Date/Time for AMA LIMS	Date of Last Use (MM/DD/YYYY)	Time of Last Use (Military time, ie, 08:00 or 16:00)	Sample Purpose (Select from Drop-Down Options)
-1	1	BSES-1	First-Draw	1: BSES-1 First-Draw	Combination Sink - Faucet, Cold	Yes (= Consumption)	Kitchen		Faucet	Main Bldg	1st Floor	Combination Sink - Faucet, Cold, Yes (= Consumption), Kitchen, , Faucet, Main Bldg, 1st Floor	12/20/2023	05:27	12/20/2023 5:27 AM	12/19/2023	16:32	Standard/Routine
-2	2	BSES-3	First-Draw	2: BSES-3 First-Draw	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Cafeteria		Bubbler	Main Bldg	1st Floor	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Cafeteria, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:25	12/20/2023 5:25 AM	12/19/2023	16:31	Standard/Routine
-3	3	BSES-3BW	First-Draw	3: BSES-3BW First-Draw	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler	Yes (= Consumption)	Cafeteria		Bottle Fill	Main Bldg	1st Floor	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Cafeteria, , Bottle Fill, Main Bldg, 1st Floor	12/19/2023	05:37	12/19/2023 5:37 AM	12/18/2023	21:00	Standard/Routine
-4	4	BSES-4	First-Draw	4: BSES-4 First-Draw	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Hallway		Bubbler	Main Bldg	1st Floor	Drinking Water Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:29	12/20/2023 5:29 AM	12/19/2023	16:28	Standard/Routine
-5	5	BSES-6	First-Draw	5: BSES-6 First-Draw	Faucet, Cold	Yes (= Consumption)	Office		Faucet	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Office, , Faucet, Main Bldg, 1st Floor	12/20/2023	05:19	12/20/2023 5:19 AM	12/19/2023	16:26	Standard/Routine
-6	6	BSES-7	First-Draw	6: BSES-7 First-Draw	Faucet, Cold	Yes (= Consumption)	Nurse's Office/Health Room		Faucet	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Faucet, Main Bldg, 1st Floor	12/20/2023	05:20	12/20/2023 5:20 AM	12/19/2023	16:27	Standard/Routine
-7	7	BSES-8	First-Draw	7: BSES-8 First-Draw	Faucet, Cold	Yes (= Consumption)	Nurse's Office/Health Room		Faucet	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Faucet, Main Bldg, 1st Floor	12/20/2023	05:21	12/20/2023 5:21 AM	12/19/2023	16:27	Standard/Routine
-8	8	BSES-9F	First-Draw	8: BSES-9F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:32	12/20/2023 5:32 AM	12/19/2023	16:27	Standard/Routine
-9	9	BSES-10F	First-Draw	9: BSES-10F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:33	12/20/2023 5:33 AM	12/19/2023	16:28	Standard/Routine
-10	10	BSES-11F	First-Draw	10: BSES-11F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:34	12/20/2023 5:34 AM	12/19/2023	16:29	Standard/Routine
-11	11	BSES-12F	First-Draw	11: BSES-12F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:35	12/20/2023 5:35 AM	12/19/2023	16:31	Standard/Routine
-12	12	BSES-13F	First-Draw	12: BSES-13F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:36	12/20/2023 5:36 AM	12/19/2023	16:46	Standard/Routine
-13	13	BSES-14F	First-Draw	13: BSES-14F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:40	12/20/2023 5:40 AM	12/19/2023	16:48	Standard/Routine
-14	14	BSES-15	First-Draw	14: BSES-15 First-Draw	Faucet, Cold	Yes (= Consumption)	Teachers' Lounge/Break Room		Faucet	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, , Faucet, Main Bldg, 1st Floor	12/20/2023	05:38	12/20/2023 5:38 AM	12/19/2023	16:32	Standard/Routine
-15	15	BSES-16	First-Draw	15: BSES-16 First-Draw	Refrigerator Water Dispenser - Not required if non-metal water line	Yes (= Consumption)	Teachers' Lounge/Break Room		Dispenser	Main Bldg	1st Floor	Refrigerator Water Dispenser - Not required if non-metal water line, Yes (= Consumption), Teachers' Lounge/Break Room, , Dispenser, Main Bldg, 1st Floor	12/20/2023	05:39	12/20/2023 5:39 AM	12/19/2023	16:40	Standard/Routine
-16	16	BSES-17F	First-Draw	16: BSES-17F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:41	12/20/2023 5:41 AM	12/19/2023	16:49	Standard/Routine
-17	17	BSES-18F	First-Draw	17: BSES-18F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:42	12/20/2023 5:42 AM	12/19/2023	16:51	Standard/Routine
-18	18	BSES-19	First-Draw	18: BSES-19 First-Draw	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Hallway		Bubbler	Main Bldg	1st Floor	Drinking Water Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:43	12/20/2023 5:43 AM	12/19/2023	17:03	Standard/Routine
-19	19	BSES-20F	First-Draw	19: BSES-20F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:44	12/20/2023 5:44 AM	12/19/2023	16:53	Standard/Routine
-20	20	BSES-21F	First-Draw	20: BSES-21F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:45	12/20/2023 5:45 AM	12/19/2023	17:01	Standard/Routine
-21	21	BSES-22F	First-Draw	21: BSES-22F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:46	12/20/2023 5:46 AM	12/19/2023	17:02	Standard/Routine
-22	22	BSES-24F	First-Draw	22: BSES-24F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:50	12/20/2023 5:50 AM	12/19/2023	17:03	Standard/Routine
-23	23	BSES-25F	First-Draw	23: BSES-25F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:50	12/20/2023 5:50 AM	12/19/2023	17:05	Standard/Routine
-24	24	BSES-27F	First-Draw	24: BSES-27F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:51	12/20/2023 5:51 AM	12/19/2023	17:10	Standard/Routine
-25	25	BSES-28F	First-Draw	25: BSES-28F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:51	12/20/2023 5:51 AM	12/19/2023	17:12	Standard/Routine
-26	26	BSES-29F	First-Draw	26: BSES-29F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:52	12/20/2023 5:52 AM	12/19/2023	17:17	Standard/Routine
-27	27	BSES-30F	First-Draw	27: BSES-30F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:55	12/20/2023 5:55 AM	12/19/2023	17:24	Standard/Routine
-28	28	BSES-31F	First-Draw	28: BSES-31F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:55	12/20/2023 5:55 AM	12/19/2023	17:17	Standard/Routine
-29	29	BSES-33F	First-Draw	29: BSES-33F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:56	12/20/2023 5:56 AM	12/19/2023	17:13	Standard/Routine
-30	30	BSES-34F	First-Draw	30: BSES-34F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:57	12/20/2023 5:57 AM	12/19/2023	17:15	Standard/Routine
-31	31	BSES-35F	First-Draw	31: BSES-35F First-Draw	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Drinking Water Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:54	12/20/2023 5:54 AM	12/19/2023	16:57	Standard/Routine
-32	32	BSES-36F	First-Draw	32: BSES-36F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	05:54	12/20/2023 5:54 AM	12/19/2023	16:56	Standard/Routine
-33	33	BSES-39F	First-Draw	33: BSES-39F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	06:00	12/20/2023 6:00 AM	12/19/2023	17:01	Standard/Routine
-34	34	BSES-40F	First-Draw	34: BSES-40F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	06:01	12/20/2023 6:01 AM	12/19/2023	17:00	Standard/Routine
-35	35	BSES-41F	First-Draw	35: BSES-41F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubbler, Main Bldg, 1st Floor	12/20/2023	06:03	12/20/2023 6:03 AM	12/19/2023	17:30	Standard/Routine



AMA Analytical Services, Inc.

Focused On Results.

E-COC Pb H2O at MD Schools
Howard County Public School System
10910 Clarksville Pike
Ellicott City, MD 21042
(410) 313-6600

COC#: **654038**

School Name: Bellow Springs Elementary School

Address: 8125 Old Stockbridge Drive, Ellicott City, MD 21043

County: Howard County

MSDE ID #: 13.078

Project Manager: Christopher Madden

PM Cell Phone No.: 410-313-8874

Email Results To: christopher_madden@hcpss.org

Email Invoice To: christopher_madden@hcpss.org

Samples Collected by: Christopher Madden

Sampler's Phone Number: 410-313-6699

Sampler's Affiliation: Howard County Public School System

Turn-Around-Time: **5-Day**

Due Date & Time: **1/3/2024 5:00 PM**

Enter as MM/DD/YYYY HH:MM

Start Date & Time: 12/19/2023 5:37AM & 12/20/2023 5:19AM

Stop Date & Time: 12/19/2023 5:37AM & 12/20/2023 6:25AM

Enter as MM/DD/YYYY HH:MM

Sample Collection Data

NOTES: ONLY ANALYZE FLUSH SAMPLE (#53) IF ASSOCIATED 1ST DRAW SAMPLE (#1) IS > 5.5 PPB

AMA ID	Bottle ID # (Label bottle submitted to lab w/ this ID #)	Outlet ID Code (Unique ID for each Outlet)	Draw Type (First Draw or Flush)	Sample ID for AMA LIMS	Outlet Type (Select from the Drop-Down Options)	Outlet Use (Consumption or Non-Consumption)	Outlet Area Type (Select from Drop-Down Options)	Outlet Location Description (Be as detailed as possible, ie, between Room #23 & 25)	Outlet Description (Be as detailed as possible, ie, Left Bubblers)	Building ID (Only required if school has multiple buildings, ie, Main Bldg, Tablet 1)	Building Floor (Use "1" if Bldg is single floor)	Sample Location for AMA LIMS	Date Collected (MM/DD/YYYY)	Time Collected (Military time, ie 08:00 or 16:00)	Collection Date/Time for AMA LIMS	Date of Last Use (MM/DD/YYYY)	Time of Last Use (Military time, ie 08:00 or 16:00)	Sample Purpose (Select from Drop-Down Options)
-36	36	BSES-42F	First-Draw	36: BSES-42F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	05:58	12/20/2023 5:58 AM	12/19/2023	16:56	Standard/Routine
-37	37	BSES-43	First-Draw	37: BSES-43 First-Draw	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Hallway		Bubbler	Main Bldg	1st Floor	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:04	12/20/2023 6:04 AM	12/19/2023	16:56	Standard/Routine
-38	38	BSES-44F	First-Draw	38: BSES-44F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:05	12/20/2023 6:05 AM	12/19/2023	16:55	Standard/Routine
-39	39	BSES-45F	First-Draw	39: BSES-45F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:06	12/20/2023 6:06 AM	12/19/2023	16:53	Standard/Routine
-40	40	BSES-50F	First-Draw	40: BSES-50F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:08	12/20/2023 6:08 AM	12/19/2023	16:53	Standard/Routine
-41	41	BSES-51F	First-Draw	41: BSES-51F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:08	12/20/2023 6:08 AM	12/19/2023	16:52	Standard/Routine
-42	42	BSES-54F	First-Draw	42: BSES-54F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:09	12/20/2023 6:09 AM	12/19/2023	16:52	Standard/Routine
-43	43	BSES-55F	First-Draw	43: BSES-55F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:10	12/20/2023 6:10 AM	12/19/2023	16:48	Standard/Routine
-44	44	BSES-56F	First-Draw	44: BSES-56F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:11	12/20/2023 6:11 AM	12/19/2023	16:52	Standard/Routine
-45	45	BSES-57F	First-Draw	45: BSES-57F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:12	12/20/2023 6:12 AM	12/19/2023	16:53	Standard/Routine
-46	46	BSES-59F	First-Draw	46: BSES-59F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:13	12/20/2023 6:13 AM	12/19/2023	16:52	Standard/Routine
-47	47	BSES-60F	First-Draw	47: BSES-60F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:14	12/20/2023 6:14 AM	12/19/2023	16:52	Standard/Routine
-48	48	BSES-61F	First-Draw	48: BSES-61F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:16	12/20/2023 6:16 AM	12/19/2023	16:53	Standard/Routine
-49	49	BSES-62F	First-Draw	49: BSES-62F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:18	12/20/2023 6:18 AM	12/19/2023	16:51	Standard/Routine
-50	50	BSES-65F	First-Draw	50: BSES-65F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:20	12/20/2023 6:20 AM	12/19/2023	16:50	Standard/Routine
-51	51	BSES-66F	First-Draw	51: BSES-66F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:20	12/20/2023 6:20 AM	12/19/2023	16:49	Standard/Routine
-52	52	BSES-68	First-Draw	52: BSES-68 First-Draw	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Hallway		Bubbler	Main Bldg	1st Floor	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, Bubblers, Main Bldg, 1st Floor	12/20/2023	06:17	12/20/2023 6:17 AM	12/19/2023	16:53	Standard/Routine
-53	54	BSES-1	Flush	54: BSES-1 Flush	Faucet, Cold	Yes (= Consumption)	Kitchen		Faucet	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Kitchen, Faucet, Main Bldg, 1st Floor	12/20/2023	06:25	12/20/2023 6:25 AM	12/19/2023	16:32	Required Flush (collected after elevated first-draw result prior to remediation)

(NOTE: Please delete unused rows prior to emailing this E-COC to info@amalab.com & kmaxwell@amalab.com)

Sign Name

Enter As MM/DD/YYYY HH:MM

i.e., In-Person, FedEx, UPS, Courier, etc.

Relinquished by:	John D. Farmer III	<i>John D. Farmer III</i>	Date & Time:	12/20/2023 8:08 AM	Via:	AMA Courier
Received by:	Dana Nicodemus Hudson	<i>Dana Nicodemus Hudson</i>	Date & Time:	12/22/2023 10:00 AM	Via:	Pick Up