

CERTIFICATE OF ANALYSIS

Chain of Custody: 655074	Job Name: Worthington Elementary School	Date Submitted: 02/02/2024
Client: Howard County Public School System	Job Location: 4570 Roundhill Road, Ellicott City, MD 21043	Date Analyzed: 02/07/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: 13.010	Report Date: 02/08/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 01/25/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
655074-1	1: WOES-1 Flush	01/25/2024 6:25 AM	Faucet, Cold, Yes (= Consumption), Kitchen, , Right Handsink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	
655074-2	2: WOES-2 First-Draw	01/25/2024 5:50 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-3	3: WOES-3 First-Draw	01/25/2024 5:51 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-4	4: WOES-6 First-Draw	01/25/2024 5:54 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-5	5: WOES-7F First-Draw	01/25/2024 5:55 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-6	6: WOES-8F First-Draw	01/25/2024 5:55 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-7	7: WOES-9F First-Draw	01/25/2024 5:57 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-8	8: WOES-10F First-Draw	01/25/2024 5:58 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, , Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-9	9: WOES-11 First-Draw	01/25/2024 5:59 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-10	10: WOES-13 First-Draw	01/25/2024 6:01 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.84 ug/L	
655074-11	11: WOES-17 First-Draw	01/25/2024 6:03 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-12	12: WOES-19 First-Draw	01/25/2024 6:03 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.55 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody: 655074	Job Name: Worthington Elementary School	Date Submitted: 02/02/2024
Client: Howard County Public School System	Job Location: 4570 Roundhill Road, Ellicott City, MD 21043	Date Analyzed: 02/07/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: 13.010	Report Date: 02/08/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 01/25/2024 Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
655074-13	13: WOES-21 First-Draw	01/25/2024 6:05 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-14	14: WOES-24 First-Draw	01/25/2024 6:05 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-15	15: WOES-25 First-Draw	01/25/2024 6:06 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-16	16: WOES-26 First-Draw	01/25/2024 6:08 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
655074-17	17: WOES-29 First-Draw	01/25/2024 6:08 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-18	18: WOES-30 First-Draw	01/25/2024 6:10 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-19	19: WOES-33 First-Draw	01/25/2024 6:11 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-20	20: WOES-36 First-Draw	01/25/2024 6:12 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-21	21: WOES-37 First-Draw	01/25/2024 6:14 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-22	22: WOES-38S First-Draw	01/25/2024 6:17 AM	Combination Sink - Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
655074-23	23: WOES-39 First-Draw	01/25/2024 6:23 AM	Faucet, Cold, Yes (= Consumption), Media Center, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.53 ug/L	
655074-24	24: WOES-40 First-Draw	01/25/2024 6:19 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

Sample Collector: Christopher Madden
Certification:

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)
Preparation Method: None

CERTIFICATE OF ANALYSIS

Chain of Custody: 655074	Job Name: Worthington Elementary School	Date Submitted: 02/02/2024
Client: Howard County Public School System	Job Location: 4570 Roundhill Road, Ellicott City, MD 21043	Date Analyzed: 02/07/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: 13.010	Report Date: 02/08/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 01/25/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided				All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.				

Analyst(s): Paul Littleton



Technical Director _____
George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.



QC Summary for SDG #78910

Overview

Analysis Type: ICP
Sample Type: Lead Water
Analysis Date: 02/07/2024

Samples Included

655074-21, 655074-22, 655074-23, 655074-24

Preparation Blank

Result: 0.000 ppm

Report Limit Verification Sample

Percent Recovery: 109.8 %

Duplicates

RPD: N/A

Matrix Spike Analysis

Spiked Sample Percent Recovery: 97.6%
Spike Duplicate Percent Recovery: 97.8%
RPD: 0.2%

Matrix Blank

Result: 0.000 ppm

Lab Control Sample #1

Percent Recovery: 89.74 %

Lab Control Sample #2

Percent Recovery: 92.92 %

Reference Sample

Percent Recovery: 103.8%

Calibration Curve

Correlation: 1.0

Serial Dilution / Bench Spike

Serial Dilution RPD: N/A
Bench Spike Percent Recovery: N/A

Notes

Both Duplicate results are below the reporting limit, making RPD limits for these QC samples not applicable.



QC Summary for SDG #78911

Overview

Analysis Type: ICP
Sample Type: Lead Water
Analysis Date: 02/07/2024

Samples Included

655074-1, 655074-2, 655074-3, 655074-4, 655074-5, 655074-6, 655074-7, 655074-8, 655074-9, 655074-10, 655074-11, 655074-12, 655074-13, 655074-14, 655074-15, 655074-16, 655074-17, 655074-18, 655074-19, 655074-20

Preparation Blank

Result: 0.000 ppm

Report Limit Verification Sample

Percent Recovery: 102.4 %

Duplicates

RPD: N/A

Matrix Spike Analysis

Spiked Sample Percent Recovery: 96.3%
Spike Duplicate Percent Recovery: 96.5%
RPD: 0.1%

Matrix Blank

Result: 0.000 ppm

Lab Control Sample #1

Percent Recovery: 98.36 %

Lab Control Sample #2

Percent Recovery: 95.77 %

Reference Sample

Percent Recovery: 104.6%

Calibration Curve

Correlation: 1.0

Serial Dilution / Bench Spike

Serial Dilution RPD: N/A
Bench Spike Percent Recovery: N/A

Notes



School Name: Worthington Elementary School
Address: 4570 Roundhill Road, Ellicott City, MD 21043
County: Howard
MSDE ID #: 13.010

Project Manager: Christopher Madden
PM Cell Phone No.: 410-313-8874
Email Results To: christopher_madden@hcpss.org
Email Invoice To: christopher_madden@hcpss.org

Samples Collected by: Christopher Madden
Sampler's Phone Number: 410-313-6699
Sampler's Affiliation: Howard County Public School System

Turn-Around-Time: 5-Day
Due Date & Time: 2/9/2024 5:00 PM

Start Date & Time: 1/25/2024 5:50 AM
Stop Date & Time: 1/25/2024 6:25 AM

Sample Collection Data

AMA ID	Bottle ID # (Label bottle submitted to lab or the ID #)	Outlet ID Code (Unique ID for each outlet)	Draw Type (First Draw or Flush)	Sample ID for AMA LIMS	Outlet Type (Select from the Drop-Down Options)	Outlet Use (Consumption or Non-Consumption)	Outlet Area Type (Select from Drop-Down Options)	Outlet Location Description (Be as detailed as possible, i.e. between Rooms 123 & 120)	Outlet Description (Be as detailed as possible, i.e. Left Bubblers)	Building ID (Only required if school has multiple buildings; i.e. Main Bldg, Trailer 1)	Building Floor (Use "1" if Bldg is 3000-5000)	Sample Location for AMA LIMS	Date Collected (MM/YYYY)	Time Collected (HH:MM)	Collection Date/Time for AMA LIMS	Date of Last Use (MM/YYYY)	Time of Last Use (HH:MM)	Sample Purpose (Select from Drop-Down Options)
-1	1	WOES-1	Flush	1: WOES-1 Flush	Faucet, Cold	Yes (= Consumption)	Kitchen		Right Handsink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Kitchen, Right Handsink, Main Bldg, 1st Floor	1/25/2024	6:25	1/25/2024 6:25 AM	1/24/2024	17:53	Extra/Special
-2	2	WOES-2	First-Draw	2: WOES-2 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Cafeteria		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, Fountain, Main Bldg, 1st Floor	1/25/2024	5:50	1/25/2024 5:50 AM	1/24/2024	17:42	Standard/Routine
-3	3	WOES-3	First-Draw	3: WOES-3 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Cafeteria		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, Fountain, Main Bldg, 1st Floor	1/25/2024	5:51	1/25/2024 5:51 AM	1/24/2024	17:42	Standard/Routine
-4	4	WOES-6	First-Draw	4: WOES-6 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	5:54	1/25/2024 5:54 AM	1/24/2024	17:23	Standard/Routine
-5	5	WOES-7F	First-Draw	5: WOES-7F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubbler, Main Bldg, 1st Floor	1/25/2024	5:55	1/25/2024 5:55 AM	1/24/2024	17:23	Standard/Routine
-6	6	WOES-8F	First-Draw	6: WOES-8F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubbler, Main Bldg, 1st Floor	1/25/2024	5:55	1/25/2024 5:55 AM	1/24/2024	17:23	Standard/Routine
-7	7	WOES-9F	First-Draw	7: WOES-9F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubbler, Main Bldg, 1st Floor	1/25/2024	5:57	1/25/2024 5:57 AM	1/24/2024	17:25	Standard/Routine
-8	8	WOES-10F	First-Draw	8: WOES-10F First-Draw	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Yes (= Consumption)	Classroom		Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, Bubbler, Main Bldg, 1st Floor	1/25/2024	5:58	1/25/2024 5:58 AM	1/24/2024	17:25	Standard/Routine
-9	9	WOES-11	First-Draw	9: WOES-11 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Hallway		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, Fountain, Main Bldg, 1st Floor	1/25/2024	5:59	1/25/2024 5:59 AM	1/24/2024	17:22	Standard/Routine
-10	10	WOES-13	First-Draw	10: WOES-13 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:01	1/25/2024 6:01 AM	1/24/2024	17:26	Standard/Routine
-11	11	WOES-17	First-Draw	11: WOES-17 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:03	1/25/2024 6:03 AM	1/24/2024	17:45	Standard/Routine
-12	12	WOES-19	First-Draw	12: WOES-19 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:03	1/25/2024 6:03 AM	1/24/2024	17:45	Standard/Routine
-13	13	WOES-21	First-Draw	13: WOES-21 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:05	1/25/2024 6:05 AM	1/24/2024	17:44	Standard/Routine
-14	14	WOES-24	First-Draw	14: WOES-24 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:05	1/25/2024 6:05 AM	1/24/2024	17:44	Standard/Routine
-15	15	WOES-25	First-Draw	15: WOES-25 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Hallway		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, Fountain, Main Bldg, 1st Floor	1/25/2024	6:06	1/25/2024 6:06 AM	1/24/2024	17:43	Standard/Routine
-16	16	WOES-26	First-Draw	16: WOES-26 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:08	1/25/2024 6:08 AM	1/24/2024	17:42	Standard/Routine
-17	17	WOES-29	First-Draw	17: WOES-29 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:08	1/25/2024 6:08 AM	1/24/2024	17:41	Standard/Routine
-18	18	WOES-30	First-Draw	18: WOES-30 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:10	1/25/2024 6:10 AM	1/24/2024	17:39	Standard/Routine
-19	19	WOES-33	First-Draw	19: WOES-33 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:11	1/25/2024 6:11 AM	1/24/2024	17:39	Standard/Routine
-20	20	WOES-36	First-Draw	20: WOES-36 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom		Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, Fountain, Main Bldg, 1st Floor	1/25/2024	6:12	1/25/2024 6:12 AM	1/24/2024	17:32	Standard/Routine
-21	21	WOES-37	First-Draw	21: WOES-37 First-Draw	Faucet, Cold	Yes (= Consumption)	Teachers' Lounge/Break Room		Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, Sink, Main Bldg, 1st Floor	1/25/2024	6:14	1/25/2024 6:14 AM	1/24/2024	17:30	Standard/Routine
-22	22	WOES-38S	First-Draw	22: WOES-38S First-Draw	Combination Sink - Faucet, Cold	Yes (= Consumption)	Nurse's Office/Health Room		Sink	Main Bldg	1st Floor	Combination Sink - Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, Sink, Main Bldg, 1st Floor	1/25/2024	6:17	1/25/2024 6:17 AM	1/24/2024	17:25	Standard/Routine
-23	23	WOES-39	First-Draw	23: WOES-39 First-Draw	Faucet, Cold	Yes (= Consumption)	Media Center		Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Media Center, Sink, Main Bldg, 1st Floor	1/25/2024	6:23	1/25/2024 6:23 AM	1/24/2024	17:36	Standard/Routine
-24	24	WOES-40	First-Draw	24: WOES-40 First-Draw	Faucet, Cold	Yes (= Consumption)	Nurse's Office/Health Room		Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, Sink, Main Bldg, 1st Floor	1/25/2024	6:19	1/25/2024 6:19 AM	1/24/2024	17:26	Standard/Routine

(NOTE: Please delete unused rows prior to emailing this E-COC to info@amalab.com & tmaxwell@amalab.com)
 Print Name Sign Name Enter As MM/YYYY HH:MM

i.e., In-Person, FedEx, UPS, Courier, etc.

Relinquished by:	John D. Farmer III	<i>John D. Farmer III</i>	Date & Time:	1/29/2024 7:43 AM	Via:	AMA Courier
Received by:	Dana Nicodemus Hudson	<i>Dana Nicodemus Hudson</i>	Date & Time:	2/5/2024 10:30 AM	Via:	Pick Up