

CERTIFICATE OF ANALYSIS

Chain of Custody: 657416	Job Name: Guilford Park High School	Date Submitted: 04/26/2024
Client: Howard County Public School System	Job Location: 8500 Ridgelys Run Road, Jessup, MD 20794	Date Analyzed: 05/05/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: Not Provided	Report Date: 05/07/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 04/17/2024 - 04/19/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
657416-1	1: GPHS-1 First Draw	04/19/2024 5:05 AM	Ice Machine (Stand Alone), Yes (= Consumption), Kitchen, , Ice Maker, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-2	2: GPHS-2 First-Draw	04/19/2024 5:08 AM	Faucet, Cold, Yes (= Consumption), Kitchen, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-3	3: GPHS-3 First-Draw	04/19/2024 5:09 AM	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle), Yes (= Consumption), Kitchen, , Kettle, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-4	4: GPHS-4 First-Draw	04/19/2024 5:10 AM	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle), Yes (= Consumption), Kitchen, , Kettle, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-5	5: GPHS-5 First-Draw	04/19/2024 5:10 AM	Faucet, Cold, Yes (= Consumption), Kitchen, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.56 ug/L	
657416-6	6: GPHS-6 First-Draw	04/19/2024 5:11 AM	Faucet, Cold, Yes (= Consumption), Kitchen, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.3 ug/L	
657416-7	7: GPHS-7 First-Draw	04/19/2024 5:14 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-8	8: GPHS-8 First-Draw	04/19/2024 5:14 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-9	9: GPHS-8BW First-Draw	04/17/2024 6:56 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Cafeteria, , Bottle Filter, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-10	10: GPHS-9 First-Draw	04/19/2024 5:17 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-11	11: GPHS-9BW First-Draw	04/17/2024 6:57 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filter, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-12	12: GPHS-10 First-Draw	04/19/2024 5:17 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-13	13: GPHS-11 First-Draw	04/19/2024 5:20 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody: 657416	Job Name: Guilford Park High School	Date Submitted: 04/26/2024
Client: Howard County Public School System	Job Location: 8500 Ridgelys Run Road, Jessup, MD 20794	Date Analyzed: 05/05/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: Not Provided	Report Date: 05/07/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 04/17/2024 - 04/19/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
657416-14	14: GPHS-12 First-Draw	04/19/2024 5:22 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-15	15: GPHS-13 First-Draw	04/19/2024 5:24 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-16	16: GPHS-14 First-Draw	04/19/2024 5:28 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-17	17: GPHS-14BW First-Draw	04/17/2024 6:54 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Classroom, , Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-18	18: GPHS-15 First-Draw	04/19/2024 5:31 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-19	19: GPHS-16 First-Draw	04/19/2024 5:32 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-20	20: GPHS-16BW First-Draw	04/17/2024 6:51 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-21	21: GPHS-17 First-Draw	04/19/2024 5:34 AM	Faucet, Cold, Yes (= Consumption), Concessions, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-22	22: GPHS-18 First-Draw	04/19/2024 5:35 AM	Ice Machine (Stand Alone), Yes (= Consumption), Concessions, , Ice Maker, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-23	23: GPHS-19 First-Draw	04/19/2024 5:37 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Gymnasium, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-24	24: GPHS-19BW First-Draw	04/17/2024 6:50 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Gymnasium, , Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-25	25: GPHS-20 First-Draw	04/19/2024 5:39 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Gymnasium, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-26	26: GPHS-21 First-Draw	04/19/2024 5:41 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (=	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody: 657416	Job Name: Guilford Park High School	Date Submitted: 04/26/2024
Client: Howard County Public School System	Job Location: 8500 Ridgelys Run Road, Jessup, MD 20794	Date Analyzed: 05/05/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: Not Provided	Report Date: 05/07/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 04/17/2024 - 04/19/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
			Consumption), Hallway, , Fountain, Main Bldg, 1st Floor					
657416-27	28: GPHS-22 First-Draw	04/19/2024 5:42 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-28	29: GPHS-23 First-Draw	04/19/2024 5:44 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-29	30: GPHS-24 First-Draw	04/19/2024 5:45 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-30	31: GPHS-24BW First-Draw	04/17/2024 7:00 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-31	32: GPHS-25S First-Draw	04/17/2024 6:45 AM	Combination Sink - Faucet, Cold, Yes (= Consumption), Multi Purpose Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.85 ug/L	
657416-32	33: GPHS-25F First-Draw	04/19/2024 5:47 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Multi Purpose Room, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-33	34: GPHS-26 First-Draw	04/19/2024 5:49 AM	Faucet, Cold, Yes (= Consumption), Multi Purpose Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.66 ug/L	
657416-34	35: GPHS-27 First-Draw	04/19/2024 5:50 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-35	36: GPHS-28 First-Draw	04/19/2024 5:51 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-36	37: GPHS-28BW First-Draw	04/17/2024 6:45 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-37	38: GPHS-29 First-Draw	04/19/2024 5:53 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-38	39: GPHS-30 First-Draw	04/19/2024 5:56 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody: 657416	Job Name: Guilford Park High School	Date Submitted: 04/26/2024
Client: Howard County Public School System	Job Location: 8500 Ridgelys Run Road, Jessup, MD 20794	Date Analyzed: 05/05/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: Not Provided	Report Date: 05/07/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 04/17/2024 - 04/19/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
657416-39	40: GPHS-31 First-Draw	04/19/2024 5:56 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-40	41: GPHS-32 First-Draw	04/19/2024 5:58 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-41	42: GPHS-33 First-Draw	04/19/2024 5:59 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-42	43: GPHS-34 First-Draw	04/19/2024 6:00 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-43	44: GPHS-35 First-Draw	04/19/2024 6:01 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-44	45: GPHS-36 First-Draw	04/19/2024 6:04 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-45	46: GPHS-37 First-Draw	04/19/2024 6:04 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-46	47: GPHS-38 First-Draw	04/19/2024 6:07 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-47	48: GPHS-39 First-Draw	04/19/2024 6:08 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, , Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.53 ug/L	
657416-48	49: GPHS-40 First-Draw	04/19/2024 6:10 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-49	50: GPHS-40BW First-Draw	04/17/2024 6:57 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-50	51: GPHS-41 First-Draw	04/19/2024 6:11 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-51	52: GPHS-42 First-Draw	04/19/2024 6:15 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, , Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-52	53: GPHS-43 First-Draw	04/19/2024 6:17 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-53	54: GPHS-44 First-Draw	04/19/2024 6:18 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody: 657416	Job Name: Guilford Park High School	Date Submitted: 04/26/2024
Client: Howard County Public School System	Job Location: 8500 Ridgelys Run Road, Jessup, MD 20794	Date Analyzed: 05/05/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: Not Provided	Report Date: 05/07/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 04/17/2024 - 04/19/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
657416-54	55: GPHS-44BW First-Draw	04/17/2024 6:40 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-55	56: GPHS-45 First-Draw	04/19/2024 6:20 AM	Faucet, Cold, Yes (= Consumption), Other, , Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-56	57: GPHS-46 First-Draw	04/19/2024 6:22 AM	Faucet, Cold, Yes (= Consumption), Media Center, , Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-57	58: GPHS-48 First-Draw	04/19/2024 6:24 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-58	59: GPHS-48BW First-Draw	04/17/2024 6:40 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-59	60: GPHS-49 First-Draw	04/19/2024 6:26 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, , Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-60	61: GPHS-50 First-Draw	04/19/2024 6:34 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, , Sink, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-61	62: GPHS-51 First-Draw	04/19/2024 6:36 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-62	63: GPHS-52 First-Draw	04/19/2024 6:37 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-63	64: GPHS-52BW First-Draw	04/17/2024 6:37 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-64	65: GPHS-53 First-Draw	04/19/2024 6:39 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, , Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	0.87 ug/L	
657416-65	66: GPHS-54 First-Draw	04/19/2024 6:41 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-66	67: GPHS-55 First-Draw	04/19/2024 6:42 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, , Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody: 657416	Job Name: Guilford Park High School	Date Submitted: 04/26/2024
Client: Howard County Public School System	Job Location: 8500 Ridgelys Run Road, Jessup, MD 20794	Date Analyzed: 05/05/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: Not Provided	Report Date: 05/07/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 04/17/2024 - 04/19/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
657416-67	68: GPHS-55BW First-Draw	04/17/2024 6:36 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, , Bottle Filler, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
657416-68	69: GPHS-56 First-Draw	04/19/2024 6:44 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, , Sink, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

Sample Collector: Kithsiri Rupasinghe & John Farmer III (BW & S)
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)
Preparation Method: None
mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

Analyst(s): Paul Littleton



Technical Director _____
George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.