

IMPORTANT NOTICE: Lead Water Sample Result

Lisbon Elementary (PWSID# MD 1130006)

SAMPLE RESULT

On September 13, 2024, five (5) lead water samples were collected from Lisbon Elementary, located at 15901 Frederick Road, Woodbine, Maryland. The Safe Drinking Water Act requires Lisbon Elementary provide each customer served by the facility on a regular basis (e.g. employees, staff, students, etc.) the results of those lead samples. The lead results from the samples collected at the above address were as follows:

Fixture #	Result (ppm)
3S (Room 181)	None Detected
7S (Room 188)	None Detected
15 (Room 166)	0.0024
30 (Room 122)	None Detected
43 (Staff Lounge)	0.0014

MAXIMUM CONTAMINANT LEVEL GOAL (MCLG) & ACTION LEVEL (AL)

The MCLG for lead is zero and the AL is 0.015 parts per million (ppm) for the 90th percentile value. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The AL is the concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow.

The 90th percentile value was 0.0019 ppm and is calculated by listing sample results from the highest to lowest value. Starting from the bottom (lowest value) count up until the calculated number (# of samples analyzed x 0.9) is reached. The sample value in this number position is the 90th percentile. If 5 samples were collected, average the 4th and 5th highest sample values to derive at the 90th percentile value.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

STEPS YOU CAN TAKE TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.
3. Look for alternative sources (e.g. bottled water) if lead levels are elevated.
4. Get your child tested. Contact your local health department or healthcare provider to find out how you can get your child tested for lead, if you are concerned about exposure.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

For additional information, please contact Christopher Madden at 410-313-8847. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead or contact your health care provider.

PWSID: MD 1130006