

CERTIFICATE OF ANALYSIS

Chain of Custody: 663910	Job Name: Clarksville Elementary School	Date Submitted: 11/25/2024
Client: Howard County Public School System	Job Location: 12041 Clarksville Pike, Clarksville, MD 21029	Date Analyzed: 12/17/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: 13.037	Report Date: 12/20/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 11/20/2024 - 11/22/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
663910-1	: CES-1 First Draw	11/20/2024 5:12 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.86 ug/L	
663910-2	: CES-2 First-Draw	11/20/2024 5:13 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.4 ug/L	
663910-3	: CES-3 First-Draw	11/20/2024 5:15 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-4	: CES-4F First-Draw	11/20/2024 5:17 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-5	: CES-7 First-Draw	11/20/2024 5:18 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-6	: CES-8 First-Draw	11/20/2024 5:20 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-7	: CES-10 First-Draw	11/20/2024 5:22 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-8	: CES-14 First-Draw	11/20/2024 5:24 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-9	: CES-15F First-Draw	11/20/2024 5:26 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	
663910-10	: CES-16F First-Draw	11/20/2024 5:28 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-11	: CES-17F First-Draw	11/20/2024 5:30 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-12	: CES-21 First-Draw	11/21/2024 6:20 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody: 663910	Job Name: Clarksville Elementary School	Date Submitted: 11/25/2024
Client: Howard County Public School System	Job Location: 12041 Clarksville Pike, Clarksville, MD 21029	Date Analyzed: 12/17/2024
Address: 10910 Route 108 Ellicott City Maryland 21042	Job Number: 13.037	Report Date: 12/20/2024
Attention: Christopher Madden	P.O. Number: Not Provided	Date Sampled: 11/20/2024 - 11/22/2024
		Person Submitting: John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
663910-13	: CES-22 First-Draw	11/20/2024 5:32 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-14	: CES-23F First-Draw	11/20/2024 5:42 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-15	: CES-24F First-Draw	11/20/2024 5:40 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	
663910-16	: CES-25F First-Draw	11/20/2024 5:38 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-17	: CES-26F First-Draw	11/20/2024 5:30 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-18	: CES-27F First-Draw	11/22/2024 6:50 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.65 ug/L	
663910-19	: CES-28 First-Draw	11/20/2024 5:44 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
663910-20	: CES-28BW First-Draw	11/21/2024 6:20 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Fill, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.91 ug/L	
663910-21	: CES-29 First-Draw	11/20/2024 5:46 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.2 ug/L	
663910-22	: CES-29 Flush	11/20/2024 5:48 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st Draw <5.5ppb

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)
Preparation Method: None
mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

Sample Collector: Christopher Madden/John Farmer
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Analyst(s): George Land



CERTIFICATE OF ANALYSIS

Chain of Custody:	663910	Job Name:	Clarksville Elementary School	Date Submitted:	11/25/2024
Client:	Howard County Public School System	Job Location:	12041 Clarksville Pike, Clarksville, MD 21029	Date Analyzed:	12/17/2024
Address:	10910 Route 108 Ellicott City Maryland 21042	Job Number:	13.037	Report Date:	12/20/2024
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	11/20/2024 - 11/22/2024
				Person Submitting:	John D. Farmer, III

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
-------------------	----------------------	-----------	----------	---------------	----------------	-----------------	--------------	----------

Technical Director _____
 George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.



QC Summary for SDG #82132

Overview

Analysis Type: ICP
Sample Type: Lead Water
Analysis Date: 12/16/2024

Samples Included

663910-21, 663910-22

Preparation Blank

Result: -0.000 ppm

Report Limit Verification Sample

Percent Recovery: 96.8 %

Duplicates

RPD: 1.3 %

Matrix Spike Analysis

Spiked Sample Percent Recovery: 92.8%
Spike Duplicate Percent Recovery: 94.5%
RPD: 1.8%

Matrix Blank

Result: -0.000 ppm

Lab Control Sample #1

Percent Recovery: 99.19 %

Lab Control Sample #2

Percent Recovery: 99.28 %

Reference Sample

Percent Recovery: 99.6%

Calibration Curve

Correlation: 1.0

Serial Dilution / Bench Spike

Serial Dilution RPD: N/A
Bench Spike Percent Recovery: N/A

Notes



QC Summary for SDG #82133

Overview

Analysis Type: ICP
Sample Type: Lead Water
Analysis Date: 12/17/2024

Samples Included

663910-1, 663910-2, 663910-3, 663910-4, 663910-5, 663910-6, 663910-7, 663910-8, 663910-9, 663910-10, 663910-11, 663910-12, 663910-13, 663910-14, 663910-15, 663910-16, 663910-17, 663910-18, 663910-19, 663910-20

Preparation Blank

Result: -0.000 ppm

Report Limit Verification Sample

Percent Recovery: 95.8 %

Duplicates

RPD: N/A

Matrix Spike Analysis

Spiked Sample Percent Recovery: 96.8%
Spike Duplicate Percent Recovery: 97.2%
RPD: 0.4%

Matrix Blank

Result: -0.000 ppm

Lab Control Sample #1

Percent Recovery: 99.35 %

Lab Control Sample #2

Percent Recovery: 98.13 %

Reference Sample

Percent Recovery: 100.6%

Calibration Curve

Correlation: 1.0

Serial Dilution / Bench Spike

Serial Dilution RPD: N/A
Bench Spike Percent Recovery: N/A

Notes



School Name: Clarksville Elementary School
Address: 12041 Clarksville Pike, Clarksville, MD 21029
County: Howard County
MSDE ID #: 13.037

Project Manager: Christopher Madden
PM Cell Phone No.: 410-313-8874
Email Results To: christopher_madden@hcpss.org
Email Invoice To: christopher_madden@hcpss.org

Samples Collected by: John Farmer and Chris Madden
Sampler's Phone Number: 410-313-8699
Sampler's Affiliation: Howard County Public School System

Turn-Around-Time: 5-Day
Due Date & Time: 12/3/2024 5:00 PM
Enter As MM/DD/YYYY HH:MM

Start Date & Time: 11/20/2024 5:12AM, 11/21/2024 6:20AM, 11/22/2024 6:50AM
Stop Date & Time: 11/20/2024 5:48AM, 11/21/2024 6:20AM, 11/22/2024 6:50AM
Enter As MM/DD/YYYY HH:MM

Sample Collection Data

ANALYZE FLUSH SAMPLE IF FIRST DRAW IS GREATER THAN 5.5 PPB

AMA ID	Bottle ID # <small>(Label number submitted to lab or Row ID #)</small>	Outlet ID Code <small>(Unique ID for each Outlet)</small>	Draw Type <small>(First Draw or Flush)</small>	Sample ID for AMA LIMS	Outlet Type <small>(Select from the Drop-Down Options)</small>	Outlet Use <small>(Consumption or Non-Consumption)</small>	Outlet Area Type <small>(Select from Drop-Down Options)</small>	Outlet Location Description <small>(Be as detailed as possible, ie. Subroom Room #, etc.)</small>	Outlet Description <small>(Be as detailed as possible, ie. Left or Right)</small>	Building ID <small>(Only required if different than multiple buildings in Main Bldg. Enter "1")</small>	Building Floor <small>(Enter "1" if 1st Floor)</small>	Sample Location for AMA LIMS	Date Collected <small>(MM/YYYY)</small>	Time Collected <small>(HH:MM)</small>	Collection Date/Time for AMA LIMS	Date of Last Use <small>(MM/YYYY)</small>	Time of Last Use <small>(HH:MM)</small>	Sample Purpose <small>(From Drop-Down Options)</small>
-1		CES-1	First Draw	CES-1 First-Draw	Faucet, Cold	Yes (= Consumption)	Nurse's Office/Health Room	See Floor Plan	Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	11/20/2024	05:12	11/20/2024 5:12 AM	1/31/2023	21:00	Standard/Routine
-2		CES-2	First-Draw	CES-2 First-Draw	Faucet, Cold	Yes (= Consumption)	Nurse's Office/Health Room	See Floor Plan	Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	11/20/2024	05:13	11/20/2024 5:13 AM	11/19/2024	21:00	Standard/Routine
-3		CES-3	First-Draw	CES-3 First-Draw	Faucet, Cold	Yes (= Consumption)	Teachers' Lounge/Break Room	See Floor Plan	Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 1st Floor	11/20/2024	05:15	11/20/2024 5:15 AM	11/19/2024	21:00	Standard/Routine
-4		CES-4F	First-Draw	CES-4F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:17	11/20/2024 5:17 AM	11/19/2024	21:00	Standard/Routine
-5		CES-7	First-Draw	CES-7 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Hallway	See Floor Plan	Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	11/20/2024	05:18	11/20/2024 5:18 AM	11/19/2024	21:00	Standard/Routine
-6		CES-8	First-Draw	CES-8 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Hallway	See Floor Plan	Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	11/20/2024	05:20	11/20/2024 5:20 AM	11/19/2024	21:00	Standard/Routine
-7		CES-10	First-Draw	CES-10 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 1st Floor	11/20/2024	05:22	11/20/2024 5:22 AM	11/19/2024	21:00	Standard/Routine
-8		CES-14	First-Draw	CES-14 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 1st Floor	11/20/2024	05:24	11/20/2024 5:24 AM	11/19/2024	21:00	Standard/Routine
-9		CES-15F	First-Draw	CES-15F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:26	11/20/2024 5:26 AM	11/19/2024	21:00	Standard/Routine
-10		CES-16F	First-Draw	CES-16F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:28	11/20/2024 5:28 AM	11/19/2024	21:00	Standard/Routine
-11		CES-17F	First-Draw	CES-17F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:30	11/20/2024 5:30 AM	11/19/2024	21:00	Standard/Routine
-12		CES-21	First-Draw	CES-21 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Hallway	See Floor Plan	Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	11/21/2024	08:20	11/21/2024 8:20 AM	11/20/2024	21:00	Standard/Routine
-13		CES-22	First-Draw	CES-22 First-Draw	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Hallway	See Floor Plan	Fountain	Main Bldg	1st Floor	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	11/20/2024	05:32	11/20/2024 5:32 AM	11/19/2024	21:00	Standard/Routine
-14		CES-23F	First-Draw	CES-23F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:42	11/20/2024 5:42 AM	11/19/2024	21:00	Standard/Routine
-15		CES-24F	First-Draw	CES-24F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:40	11/20/2024 5:40 AM	11/19/2024	21:00	Standard/Routine
-16		CES-25F	First-Draw	CES-25F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:38	11/20/2024 5:38 AM	11/19/2024	21:00	Standard/Routine
-17		CES-26F	First-Draw	CES-26F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/20/2024	05:30	11/20/2024 5:30 AM	11/19/2024	21:00	Standard/Routine
-18		CES-27F	First-Draw	CES-27F First-Draw	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Yes (= Consumption)	Classroom	See Floor Plan	Bubbler	Main Bldg	1st Floor	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	11/22/2024	06:50	11/22/2024 6:50 AM	11/21/2024	21:00	Standard/Routine
-19		CES-28	First-Draw	CES-28 First-Draw	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated)	Yes (= Consumption)	Hallway	See Floor Plan	Fountain	Main Bldg	1st Floor	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	11/20/2024	05:44	11/20/2024 5:44 AM	11/19/2024	21:00	Standard/Routine
-20		CES-28BW	First-Draw	CES-28BW First-Draw	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler	Yes (= Consumption)	Hallway	See Floor Plan	Bottle Fill	Main Bldg	1st Floor	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Fill, Main Bldg, 1st Floor	11/21/2024	08:20	11/21/2024 8:20 AM	11/20/2024	21:00	Standard/Routine
-21		CES-29	First-Draw	CES-29 First-Draw	Faucet, Cold	Yes (= Consumption)	Kitchen	See Floor Plan	Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	11/20/2024	05:46	11/20/2024 5:46 AM	11/19/2024	21:00	Standard/Routine
-22		CES-29	Flush	CES-29 Flush	Faucet, Cold	Yes (= Consumption)	Kitchen	See Floor Plan	Sink	Main Bldg	1st Floor	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	11/20/2024	05:48	11/20/2024 5:48 AM	11/19/2024	21:00	Extra/Special

(NOTE: Please delete unused rows prior to emailing this E-COC to info@amalab.com & kmaxwell@amalab.com)

Relinquished by:	JOHN FARMER	John D. Farmer III	Date & Time:	11/22/2024 7:49 AM	Via:	AMA Courier
Received by:	Dana Nicodemus Hudson	Dana Nicodemus Hudson	Date & Time:	11/25/2024 10:00 AM	Via:	Pick Up